

### **SOUTH SAN LUIS OBISPO COUNTY** SANITATION DISTRICT

Post Office Box 339 Oceano, California 93475-0339 1600 Aloha Oceano, California 93445-9735 Telephone (805) 489-6666 FAX (805) 489-2765 www.sslocsd.org

Staff Report

To: Board of Directors

From: Richard Sweet, PE, District Manager

Date: May 20, 2015

Subject: REDUNDANCY PROJECT; STATUS REPORT

### RECOMMENDATION:

That the Board receives this report and provide direction.

### BACKGROUND

also anticipate stricter discharge requirement being issued by the Regional Water Quality Control Board in an upcoming new permit. The proposal underwent a peer On February 18, 2015 the Board received a report from Kennedy/Jenks Consultants that described the Redundancy Project, Attachment "A". The report detailed that the plant that would provide plant redundancy in compliance with Environmental Protection review by John Carollo Engineers in 2010. Agency (EPA) requirements to provide redundant plant operations. The plant upgrades

The report concluded that the best alternative for the District would be to construct a new aeration tank and a new secondary clarifier. The new aeration tank would and 30 mg/l SS. Biological Oxygen Demand (BOD) and 40 mg/l Suspended Solids (SS) to 30 mg/l BOD meet both redundancy requirements and reduce the plant discharge from 40 mg/l construction of the aeration tank in conjunction with a new secondary clarifier would introduce a new treatment process to the plant referred to as activated sludge. The

#### DISCUSSION:

timely manner. To aid in the preparation of the permit the RWQCB staff requested an to place timing in the permit to allow the District to construct the plant improvement in a to lower our requirements to 30 mg/l for both SS and BOD. The RWQCB staff agreed RWQCB staff confirmed that they would be crafting the District's new discharge permit (RWQCB) staff to discuss conditions of a new discharge permit for the District's plant. On Friday, March 27, 2015 Board staff met with Regional Water Quality Control Board

from Kennedy/Jenks Consultants. implementation timeline from the District. The District has requested such a timeline

seeking estimates for those items from Kennedy/Jenks Consultants. identify costs of design, permitting and construction management. The District is with an annual projected increase in operating costs \$363,000. The report failed to The projected project costs provided by Kennedy/Jenks Consultants were \$12,061,000

for financing is the State Revolving Fund (SRF). The SRF provides financing for water related projects at approximately one-half the standard financing rates. To fund the redundancy project the District will require financing. The best opportunity

has the lowest rates of any jurisdiction in San Luis Obispo and Santa Barbara Counties notification of all customers and a protest vote. If a majority of ratepayers file a protes to the rate increase implementation of the rate increase will be prohibited. The District rate increase will be subject to the provisions of Proposition 218. This requires action to increase rates in 2006 resulting in the last rate increase occurring in 2010. A To retire the debt the District will need to seek a rate increase. The District last took If a majority of ratepayers file a protest

the fiscal year. of the results of the Bartles Wells study awaits the final estimates from Kennedy/Jenks in support of the Redundancy Project and increased operating costs. Final preparation Bartles Wells has been engaged to define financing options and potential rate increases Consultants. It is believed that this information will be available near the beginning of

Richard G. Sweet, PE District Manager

Attachments

## Kennedy/Jenks Consultants

2350 Mission College Blvd., Suite 525 Santa Clara, CA 95054 650-852-2800

### Upgrading Existing Wastewater Treatment Plant Documentation Review and Update Probable Cost

4 February 2015



Prepared for

## South San Luis Obispo County Sanitation District

1600 Aloha Place / P.O. Box 339 Oceano, California 93475

K/J Project No. 1368035\*00

### **Table of Contents**

List of Appendices	ices	
Executive Sum	mary	Executive Summary
Section 1:	Revi	Review of Prior Documents1-
	<u>-</u>	Review of District's History1-
	1.2	Area Population Projections
	1.3	
	1.4	
		Reviewed1-
	1.5	Review of Changes in Wastewater Characteristics1-9
	1.6	
	1.7	Review of Changes Affecting Financing1-10
	<u>-1</u> .8	
	1.9	Summary1-1
Section 2:	Rec	Recommended Improvement Project2-1
	2.1 2.2	New Aeration Tank2 New Secondary Clarifier2
Section 3:	Engi	Engineer's Opinion of the Probable Cost of Construction
	and	and Operation and Maintenance of Recommended Project 3-7

### **List of Appendices**

Appendix A: Appendix B: Comments on K/J Recommended Improvement Project vs Carollo Opinion of Probable Construction Cost

### **Executive Summary**

### **Review of Prior Documents**

of extending the excellent history of meeting State and Federal wastewater discharge requirements since formation of the South San Luis Obispo County Sanitation District during the consisting of additional wastewater treatment plant improvements, will be for the basic purpose conclusions and recommendations for a major District construction project. This project, The primary purpose of the information and studies presented hereinafter is for supporting the

changed conditions including more stringent waste discharge requirements. engineering studies which served as the basis for constructing a series of wastewater treatment treatment and disposal facilities during 1965, there have been a series of documents and been in response to changing conditions related to increased population served as well as plant improvements in the past and to the present. Each of the past improvement projects have During the 51 years since formation of the District and construction of the original wastewater

The most recent and comprehensive engineering study directed towards defining the currently needed wastewater treatment plant improvements is the, "Long-Range Plan for Wastewater July 7, 2005 Treatment Plant Improvements" provided by Kennedy/Jenks Consultants and under the date of

alternatives on the basis of which the District could move ahead with confidence to The 2005 Kennedy/Jenks Consultants report was followed by a Peer Review Report undertaken by Carollo Engineers and submitted to the District under the date of January 9, 2010. The recommended project implementation of the recommended improvements project, including financing of the Consultants report and recommendations. Also the Peer Review was to consider additional purpose of the Carollo Review was independently to study and to verify the Kennedy/Jenks

### Review of District's History

a sewerage system constructed by the City of Arroyo Grande in 1925. primarily accomplished through use of individual septic tanks. The exception to this practice was collection, treatment and disposal facilities, wastewater disposal within the service area was It is observed that prior to the District's formation and then construction of the wastewater

county area. 1963. The District embraced the areas of Arroyo Grande, Grover City, Oceano and contiguous District formation by the County of San Luis Obispo Board of Supervisors was on September 3

proved to be highly successful financially to the benefit of the District' constituency facilities during 1965, a series of treatment plant improvements were constructed. These wastewater facilities improvements have been financed on a "pay-as-you-go" basis which has Since construction of the District's original wastewater collection, treatment and disposal

The latest improvement project, the subject of the studies reviewed hereinafter, is anticipated to provide means of meeting District service area needs to the time of District build-out.

# Review of Changes in Service Area Population Projections

estimate wastewater collection, treatment and disposal needs of the earliest District's projects, an ultimate, build-out population of 115,000 within the District's service area. At the time, 1965, within the District's service area. These projections, which served as the basis on which to actual population was assumed to have been a total of some 15,000. County and local planning agencies developed the first projections of population increases

the 115,000 then projected population, it was decided to design for an initial population capacity Rather than designing the initial wastewater treatment plant to accommodate wastewater from

treatment plant expansions to meet short-range needs rather than projected long-range needs estimate is seen as further validation of the earlier decision to limit construction of wastewater service area resulted in an estimated build-out population of 51,300. This more current, 2005 The most recent population projections by county and local agency planners for the District's

# Review of Changes in Waste Discharge Requirements

District are and have been initiated by the Central Coast Regional Water Quality Control Board on behalf of both the State and Federal Environmental Protection Agency. Waste discharge requirements applicable to the South San Luis Obispo County Sanitation

necessitated providing added plant to meet redundancy of process units requirements. Lastly, anticipated changes in waste discharge requirements to full, "secondary" ahead of discharge later during 2014 has added to the list of needs for the now proposed treatment plant constructing new chlorination facilities. Changes in enforcement procedures has now discharge requirements. Changes in disinfection requirements resulted in the necessity of wastewater treatment plant improvements, there have been multiple changes in waste It is shown that during the years of the District's existence and construction of a series of

### Reclamation Potential Reviewed

demonstrated need and cost-effective means of providing for reclaimed water use, that use can which would meet reclamation requirements. It is anticipated that at such time there is a facilities above that now being proposed, that added costs to result in a treated wastewater treatment plant for beneficial use. These studies and to the present have all concluded for now the potential needs and possibilities for utilizing highly treated wastewater from the District's be accomplished simply by an appropriate, "add-on" to existing plant there is no sufficient market for reclaimed wastewater which would justify the added treatment Three prior studies for the District, including part of the K/J 2005 study, were directed towards

## Review of Changes in Wastewater Characteristics

for with strategic, full use of existing plant while adding facilities to meet the specific changed organics resulting form widespread use of home garbage disposal units and reduced flows. As a reduction of water use due to water saving devices, higher solids and associated dissolved changes in wastewater characteristics. These changes are seen primarily as a consequence of part of the K/J 2005 studies, these changed wastewater characteristics have been accounted As part of the normal growth pattern within the District's service area, there has been significant

# Review of Changes of Regulatory Enforcement Policies

changes in the law by the State legislature calling for strict enforcement along with monetary fines for failure to meet requirements. This State initiated change significantly has reduced the degree of discretion as to consequences of not strictly meeting all requirements. requirements through the Environmental Protection Agency in 1972 and changes, including enforcement of requirements. Part of these changes have resulted from imposition of Federal facilities, not only has there been several changes in disposal requirements, but also changes in During the intervening time since constructing the original wastewater treatment and disposal

### Review of Peer Review Report

the existing fixed film reactor and constructing an additional activated sludge aeration tank, as a next needed treatment improvement project, the District, in their wisdom, authorized a Peer Review by an independent engineering firm. The basic purpose of was to study alternatives to the K/J recommended project and to make recommendations. The basic result of the Peer part of a two-stage program of improvements. Kennedy/Jenks Consultants recommended project with one modification, to include abandoning Review Study was to offer eight alternative projects, but concluding by supporting the It is shown that upon submission of the Kennedy/Jenks Consultants 2005 report recommending

After further study of the Peer Review report by K/J and District staff, it was determined that the K/J recommended project without modification is still in the best interests of the District.

### Review of Recommended Project

New Aeration tank along with a New Secondary Clarifier and New Biosolids Thickening facilities. These new, added process units along with needed mechanical, electrical and pipework will be fully integrated into the existing plant, making strategic use of combined facilities needed to meet identified needs. The recommended wastewater treatment plant improvement project consists essentially of a

\$12,061,000 The current engineer's opinion of the probable cost for the recommended project is

# **Section 1: Review of Prior Documents**

anticipated changes including more restrictive waste discharge requirements which would development and associated increases in wastewater flow, but also relevant past and accommodate anticipated needs during the coming years. These needs include increased wastewater flows consistent with build-out as projected by local and country planning agencies anticipation of additional wastewater treatment plant improvements needed to account for summarizing studies to provide a, "Long Range Plan, Wastewater Treatment Plant Improvements for South San Luis Obispo County Sanitation District." This 2005 K/J study and dictate design of the now recommended wastewater treatment plant improvements project to occur in the year 2020. The K/J 2005 study was intended to address not only increasing recommended wastewater treatment plant improvements project identified in the report was several changed conditions, including more stringent waste discharge requirements. The Plan was initiated by the South San Luis Obispo County Sanitation District, District, in Under the date of July 7, 2005, Kennedy/Jenks Consultants (K/J) submitted their report Ö

report to the District under the date of January 9, 2010. undertaken by Carollo Engineers and their findings and recommendations were submitted in a costs and to study other potential engineering alternatives. The independent Peer Review was Following submission of the K/J 2005 studies and report, the District undertook to have a "Peer Review" of the report and to further evaluate the recommended improvements, their estimated

specific treatment plant improvements project, the District Board authorized K/J to review, with finance and construct the recommended project. To assist in a final determination of the best District staff and District Board have determined to proceed with preparation of specific plans to Since submission to the District of the two aforementioned engineering studies and reports, the improvement project are presented hereinafter. Review. Results of these prior studies along with changes relevant to the proposed District staff, the K/J 2005 report, along with the relevant studies since 2005 including the Peer

## 1.1 Review of District's History

successful treatment plant improvement projects in response to and in anticipation of needs as has responded to these changes since 1963 and to the present (2015) with a series of 5) challenges associated with needed financing of multiple project improvements. The District characteristics of wastewater to be treated, 4) changes in regulatory enforcement policies and increases, 2) changes in waste discharge requirements, 3) changes in both volume and other county and local planning agencies of future service area development and population necessary in response to changing needs resulting from, 1) major changes in projections by control collection, treatment and disposal facilities, followed by a series of plant improvements payers. The first action of the District was construction in 1965 of the original water pollution pollution control needs of the District's service area and at minimum costs to the District's rate The District since formation in 1963 has evidenced an exceptional record of meeting water District service area build-out in the year 2020. they have occurred and now projected to occur within the future to the time of anticipated

ground infiltration and evaporation. This Arroyo Grande wastewater treatment and disposal site in the Grover City area where in 1925 there was constructed an Imhoff ("primary treatment") was the City of Arroyo Grande which was largely sewered with conveyance of wastewater to a total of some 15,000 with about 6,500 in Arroyo Grande, 6,500 in (then) Grover City and 2,000 in the Oceano and other contiguous County of San Luis Obispo areas. facility was referred to as, "the sewer farm." Resident population in the area in 1963 showed a tank. Also provided were adjacent areas for disposal of the partially treated wastewater through Historically, the communities of Arroyo Grande, (then) Grover City, Oceano met their wastewater disposal needs through use of individual septic tanks. The exception to this practice

concern, and assumed to be primarily the result of wastewater intrusion into the local ground of increasing concentration of nitrates Ground water nitrates are known to be a public health made official in 1962 by the County Department of Public Health as this agency became aware water which was the primary source of potable water supply for the area. tanks and also the "sewer farm" impacting the underlying ground water. These concerns were there were increasing public health concerns related to both increasing use of individual septic With the passage of time along with increasing development of the area, it became evident that

the SSLOCSD. and to contract with SSLOCSD for treating and disposing of wastewater generated within Grover City. Subsequently Grover City, now the City of Grover City, became a full member of a member of the District, but did agree independently to provide local sewers within their area the areas of Arroyo Grande, Oceano and Grover City, along with some contiguous area within the County, would be encompassed by the District. However, Grover City chose not to become Luis Obispo County Sanitation District (SSLOCSD) on September 3, 1963. It was intended that was acted upon and the San Luis Obispo County Board of Supervisors who formed the San the combined wastewater treatment and disposal needs of the local area. This recommendation public health crises. Accordingly the Water District hired the services of then Jenks and engineering study to recommend a course of action to alleviate and forestall a water supply nitrate, the then Grover City County Water District applied for a government loan to finance an Responding to this condition of increasingly unacceptable high concentrations of ground water Results of the study included a recommendation to form a County Sanitation District to address Adamson Engineers (forerunner of Kennedy/Jenks Consultants) to perform the needed study.

The original District members as well as Grover City undertook construction of local sewer systems as needed with SSLOCSD providing, the joint-use treatment plant and ocean outfall entering the wastewater treatment plant. line to convey treated wastewater to offshore waters of the ocean as well as trunk sewers

as they became apparent. improvement projects have been constructed by the District in response to the changing needs Since building of the original wastewater treatment and disposal facilities in 1965, five major

treatment plant improvements projects to meet changing conditions. The proposed improvement project is consistent with this history. The District's exceptional history is centered on a series of successful wastewater

# Review of Changes in Service Area Population Projections

District has followed for the nearly 50 years of District existence. the anticipation of a future series of expansions and improvements as needs actually occurred. service area population of 115,000. This early decision to limit initial construction and corresponding costs for wastewater treatment facilities for a limited time into the future included ocean outfall), were designed to accommodate wastewater from the then predicted ultimate not conveniently be enlarged in the future, (trunk sewers, incoming pumping plant structure and serve a then projected 1975 population of 30,000. At the same time, those facilities which could facilities to serve the then 1965 service area population of 15,000 plus additional capacity to and disposal facilities. However, at that time it was agreed to design the initial treatment estimates in 1965 were accepted as the basis for design of the needed wastewater treatment ultimate, build-out service area population of 115,000. It was estimated that this ultimate population to be served would occur by the year 2020. These relevant planning agencies agencies. The local planning agencies population projections made in 1963 projected an population projections as defined through County of San Luis Obispo and local planning This decision was fundamental to allowing a "pay-as-you-go" financing program which the Original wastewater treatment and disposal facilities to serve the District were based on

projects than needed. This policy in has resulted in one of the lowest sewer user rates for program has served to limit borrowing of monies and consequent interest costs for larger wastewater treatment facilities allowed for a, "pay as you go" financing program. In turn this much of which would never be needed. The historic policy of limiting construction of needed serve the then projected population of 115,000 with corresponding very high costs for facilities of 115,000. Conventional wisdom may have suggested in 1965 to design all needed facilities to be served is 51,300 instead of the 1965 build-out population projection for the same time period 2020, still seen as the service area "build-out" time period, but now the projected population to to an initial 20-year planning period has been successfully followed, meeting changing needs for a relatively short time range. As suggested above, the appropriateness of this policy decision is demonstrated when viewing the 2005 county and local planning agencies projections for year similar services in the State of California. This original decision to limit construction of most of the needed wastewater treatment facilities

the more recent 2005 "build-out" projections of 51,300 in the same year of 2020. proposed facility needs. This significance, as noted above, is clearly reflected by the original, disposal facility needs are seen as being significant to the design of past and now currently In summary, the changing projections of ultimate service area wastewater treatment and 1965 planning area "build-out" population projection of 115,000 by the year 2020 compared to

appropriate for design of the proposed wastewater treatment plant improvements defined in the K/J 2005 report. After further review, the current service area projected population figure is considered

# Review of Changes in Waste Discharge Requirements

have been established for individual dischargers by the State Water Resources Control Board Requirements for treated wastewater disposal historically, since 1949, in the State of California

to be met, regardless of other conditions. This minimum standard is defined by the EPA as, "secondary" treatment as further defined by achieving an effluent quality with not more than 30 mg/l residual of both Biochemical Oxygen Demand (BOD) and Suspended Solids (SS). discharge permits also establish a minimum level of wastewater treatment ahead of discharge with the authority of both the State of California and the Federal EPA. The Federal waste EPA. Thus waste discharge requirements in the State of California are established and enforced responsibilities for establishing and enforcing waste discharge requirements jointly with the done by the District. Subsequently, the EPA delegated to some States, including California, discharged to surface waters of the entire nation including dischargers to ocean waters as being the Federal Environmental Protection Agency (EPA) and to be applicable to all treat wastewater States established the National Clean Water Elimination Act (NPDES) to be administrated by District's treated wastewater discharge in 1965, it is to be noted that the Congress of the United offices in San Luis Obispo. While waste discharge requirements were established for the Pacific Ocean are established by the Central Coast Regional Water Quality Control Board with District, discharge requirements for treated wastewater discharge into the offshore waters of the and administered through nine Regional Water Quality Control Boards. In the case of the

enforcement of the meeting of waste discharge requirements has dictated a number of minor failure to meet waste discharge requirement was set aside with the new law making generally satisfactory record of meeting requirements for the District discharge. However as a with allowable deviations from established constituent limits, including BOD, resulted in a occasional violation of the 40 mg/l BOD limitation, but the then leniency of enforcement along nearby ocean waters, along with a volume limitation of 2.5 million gallons per day (mgd) average dry-weather flow. These two limitations served as the primary basis of 1965 treatment seen as a limiting biochemical oxygen demand (BOD) of 40 mg/l for effluent discharged to the discharge to the waters of the nearby Pacific Ocean in 1965 called for a list of limitations. The improvements to accommodate increasing wastewater volume from added service area responses by the District in respect to needed treatment plant improvements aside from mandatory monetary fines for all violation of waste discharge requirements. This change in result of a change in State law in 2001, enforcement discretion as to serious impacts from even itself proved to be somewhat complex and difficult to operate. These difficulties resulted in an proved to be more than capable of meeting this 1965 requirement, the activated sludge process secondary treatment" provided by activated sludge treatment. While the original treatment plant plant design. The BOD specific requirement was met with provision of so called "intermediate most notable of these early requirements in respect to the District's treatment plant design was The original waste discharge requirements applicable to the District's treated wastewater

elimination of the use of chlorine for disinfection ahead of discharge. It was agreed at the time, some 4,000 feet into 60 feet of water depth. Studies had shown that this distance offshore constructing an entirely new ocean outfall line gaining access to the deeper waters of the ocean discharge requirements. A most notable change in requirements occurred as a result of constructed as a means of increasing efficiency of treatment as well as meeting changes in with natural die-off of harmful bacteria, would provide sufficient dilution and distance ahead of based on ocean studies, that initial dilution provided by discharge nearly one mile offshore along rather than the shorter 1,000 foot original outfall provided the basis for the RWQCB allowing the During the period of from the 1978 to 1986 several individual improvement projects were

Providing of adequate disinfection needs are seen in the context of the District's responding to at least three significant changes in waste discharge requirements during the period of from separate chlorine contact tank which was completed and placed into operation in 2006. in disinfection requirements through the design and construction of an entirely new and the building of a separate new chlorine contact tank. The District responded to this new change a result of a routine review of waste discharge requirements, the RWQCB and EPA mandated disinfection was successfully practiced and all disinfection requirements met. However, again as of using the secondary clarifier as means of providing necessary detention time for chlorine disinfection of the District's treated effluent ahead of discharge. For several years an expedient requirements by the RWQCB and EPA, requirements were changed so as to again require plant operation. Subsequently however, as part of the routine review of waste discharge to discharge saved significant expense for chlorine and so lowering overall costs of treatment associated undesirable toxic compounds would serve as added protection to nearby ocean Pismo Beach recreation area. In addition, it was agreed that eliminating use of chlorine and arriving at locations of recreation activities to ensure adequate protection of public health in the aquatic life. Also, eliminating the use of chlorine for disinfection of the treated wastewater prior

trickling filter (fixed film reactor or FFR). This allowed change in process from activated sludge RWQCB staff during 1985 brought about an agreement that District could be assigned a less suspended solids (SS) instead of the more restrictive 30 mg/l limitation. Discussions with administrative agencies could use a standard for discharge of 45 mg/l of both BOD and which, under certain circumstances such as where discharge was to offshore waters with discharge. Of special interest to the 1980's studies was a still further change in the Federal law question of anticipated waste discharge requirements changes, the meeting of which would to trickling filter FFR, provided a much more stable process and reliable meeting of basis for change in secondary treatment process of from the original activated sludge to now a restrictive, modified standard allowing for meeting of the 45 mg/l BOD and SS instead of the national secondary treatment standard of 30 mg/l. This change in requirements served as the adequate dilution, and secondary treatment was through the use of trickling filters, the local waters of the nation now called for a maximum limit of 30 mg/l residual BOD at the point of Federal EPA requirements applicable to all treated wastewater dischargers to the surface designed on the basis of meeting an effluent limitation of 40 mg/l of BOD. As also noted, dictate treatment plant expansion design. As noted above, the original treatment facilities were increased treatment flow capacity, as part of a mid-1980's study, basic to these studies, was the projections of 1965 projecting a build-out population of 115,000. In addition to needs for it is noted that this more recent population projection was considerably changed from the population to be served by the District was a combined total of 51,200 by the year 2020. Again, individual planning agencies within the District agreed that the best estimate for the build-out planning agencies became the source of projections. The combination of input from the determine additional wastewater treatment plant capacity needs. Again, county and city anticipated population increases within the District's service area prompted a new study to development along with associated increase in wastewater volume. During the early 1980's order to meet the wastewater treatment needs associated with expanding service area By the early 1980's it was evident the District's wastewater treatment plant needed expansion in results better than designed for (BOD/SS less than 45 mg/l) was "rewarded" with a change to a more restrictive discharge requirement (BOD/SS less than 40 mg/l). then the requirement should be lowered. Somewhat ironically, the District's success in achieving the BOD and SS requirements was so successful that with the subsequent routine review and meeting of project objectives. One significant additional cost-saving consequence of the change of secondary treatment process was the saving of electrical energy. This savings was seen as a waste discharge requirement of 45 mg/l BOD/SS has proven to be highly successful in necessary for construction of an entirely new, separate secondary clarifier. The 1986 treatment plant expansion, designed to accommodate 3.3 mgd (up from the original 2.5 mgd capacity) and existing structure served to significantly to reduce construction costs than would otherwise structure along with a trickling filer, FFR as a separate new structure. This novel use of an found to have residual BOD and SS, consistently lower than the then the 45 mg/l requirement, RWQCB staff had argued that since the District's treated wastewater discharge consistently was modified to require a more restrictive 40 mg/l BOD and SS instead of the 45 mg/l BOD/SS. The modification of waste discharge requirements by the RWQCB and EPA, the requirements were the overall use of electrical energy for treatment plant operation was cut in half. Also meeting of structure to be modified to provide the needed larger secondary clarifier within the same in the use of the then combined aeration tanks (for activated sludge) and secondary clarifier design of a very unique expansion of the District's treatment plant. The unique feature was seen to meet changed, less restrictive waste discharge requirements. These changes resulted in the resulted in the design of 1986 improvements to meet combined needs for capacity increase and original activated sludge process to use of a trickling filter (FFR). This change in process The foregoing changes in waste discharge requirements allowed for a switch from use of the

engineering study by Kennedy/Jenks Consultants was authorized and undertaken in 2005 anticipation of these increases with associated higher wastewater flows to be treated, a new Again, after 1986 as population increases within the District's service area were evident, and in

waste discharge requirements to be of greater stringency than at present treatment will be seen in the new requirements of October 2014. The 2005 report and standard of 30 mg/l BOD/SS now anticipated to become applicable as both State and Federal discussions resulted in the conclusion that the currently needed new treatment plant expansion project should be designed on the basis of meeting the National minimum EPA governing with RWQCB staff earlier ahead of the K/J 2005 report and most recently in April of 2014, which 2009 were preceded by requirements of 2004. It is currently anticipated that the requirements of 2009 will be reviewed and reissued in October of 2014. This consideration led to discussions approved and seen in the Central Coast Regional Water Quality Control Board, Order No. R3-209-0046 which corresponded to the Federal NPDES No. CA0048003. These requirements of expected reissuing of requirements in 2009. These then new requirements were subsequently applicable waste discharge requirements. Also this study review was in anticipation of the near and far future waste discharge requirements. The 2005 study provided a review of the then Fundamental to the 2005 study was the question of future standards to be incorporated in both recommendations for the improvement project are based on the foregoing understandings of requirements. It is understood then that this basic national standard for secondary wastewater

improvements to meet changing waste discharge requirements. The above review serves as the basis for demonstrating that the District has been totally responsive to the need to provide wastewater treatment and disposal facilities with successive

wastewater treatment plant improvements are directed toward extending this fine history requirements during the past some 50 years and that the currently recommended It is seen that the District has a fine history of responding to changing waste discharge

## Potential for Wastewater Reclamation for Beneficial Reuse Reviewed

beneficial reuse. It was observed that there have been two prior engineering studies provided to the District on this subject. One of the studies was by K/J and the other by The Wallace Group. meet demands as reclaimed water markets are developed. reclaimed water use standards. Such additional added plant could be constructed in stages to be such as to allow for accommodation of added plant improvements necessary to meet Nevertheless, it was also concluded that design of current treatment plant improvements should additional treatment facilities to meet the reclamation standards justified at the present time. future is there an identified potential market for reclaimed water such as to make the cost of Both of these studies and reports concluded that neither currently nor in the foreseeable near been in respect to potential needs and opportunities related to wastewater reclamation for An additional consideration which was reviewed as part of the K/J 2005 study and report has

significantly reduced. In any case the costs for future plant add-ons related to meeting still more stringent reclaimed water reuse standards will have been significantly reduced. quality than at present, the gap between acceptable treated wastewater for reuse will be improvements, with a basic purpose of producing an end-product effluent of significantly higher It also can be observed that with implementation of the currently recommended treatment plant

of membrane technology, either of which could be appended to the proposed improvement meet reclaimed water production meeting higher requirements would be either filtration, or use requirements for reclaimed water reuse. Given the foregoing, it is concluded that the currently recommended improvements should be designed so as conveniently to add-on treatment staff did not foresee a possible need specifically to provide for nitrogen removal as part of future justified reclaimed water market exists today, but well could exist in the future. Also, RWQCB Board (RWQCB) staff who confirmed the foregoing. It was accepted that no economically project at such time that a reclaimed water market is established. facilities, even up to improvements needed for to nitrification. The most likely added plant to As part of current studies, discussion was entered into with Regional Water Quality Contro

In other respects, it is concluded that the understandings regarding potential for plant improvement project. remain appropriate to the design of the current recommended wastewater treatment wastewater reclamation for beneficial reuse, the K/J 2005 study review of this topic

# Review of Changes in Wastewater Characteristics

strength characteristics, notably in respect to Biochemical Oxygen Demand (BOD) and Suspended Solids (SS). characteristics. These changes are to be seen in respect both the wastewater volume and completed in 1965, provided opportunity for re-evaluation of changes in wastewater The several studies during the years since design of the original wastewater treatment facilities

decreased over time. On the other-hand, increasing use of garbage disposal units along with the one-hand, through the use of water saving devices, wastewater volume per capita has the decrease in flow has served to increase wastewater strength. The changes in wastewater characteristics may be seen as a result of competing factors. On

changes in wastewater characteristics. The design basis for the current project as defined in the Kennedy/Jenks Consultants report of 2005 with the suspended solids modification are seen as confidence that the design basis for the new plant improvements adequately will account for the design basis loadings shown in the K/J 2005 report are appropriate. It is then with reasonable incoming wastewater has increased by an average of some 30 mg/l. This has suggested a change in respect to loading of from 330 mg/l to 360 mg/l. In other respects, it is concluded that improvements were able to account for the time related changes in wastewater characteristics. prior year's wastewater characteristics were analyzed, suspended solids concentration in This review resulted in a determination that during the past ten years, since 2004 when the then The K/J studies during 2005 resulting in the currently recommended treatment plant

Population served (build-out) Average wastewater volume, mgd Peak daily flow (dry-weather), mgd Peak daily flow (wet-weather), mgd Peak instantaneous wastewater flow rate, mgd Average incoming SS. mg/l Average incoming SS, lbs/day	51,200 4.2 4.9 8.4 10.0 360 12,600
Peak daily flow (dry-weather), mgd	4.9
Peak daily flow (wet-weather), mgd	8.4
Peak instantaneous wastewater flow rate, mgd	10.0
Average incoming SS. mg/l	360
Average incoming SS, lbs/day	12,600
Average incoming $BOD_5$ , $mg/l$ Average incoming $BOD_5$ , $lbs/day$	330 11,280

improvements which would be anticipate meeting projected service area needs to buildshould be utilized as the basis for design of the proposed wastewater treatment plant After review, we believe the foregoing, somewhat modified from the K/J 2005 study,

# Review of Changes of Regulatory Enforcement Policies

State Water Resources Control Board and in the case of the District, the Central Coast Regional Enforcement of waste discharge requirements in the State of California currently is through the

the nation. Notably of these universal minimum standards is Biochemical Oxygen Demand delegated by the Federal Environmental Protection Agency (EPA). This arrangement results in enforcement authority resting with both the State Water Resources Control Board and Federal (BOD) and Suspended Solids (SS) shall not be more than 30 mg/l. is seen in the EPA establishing minimum requirements for discharge into all surface waters of Clean Water Act of 1972. As has been previously noted, one of the impacts of this joint authority EPA. The joint authority came about from passage by the Congress of the United States of the Water Quality Control Board (RWQCB). Enforcement policies of the State currently are

infraction with no significant impact on the receiving water environment. viewed by the RWQCB on a discretionary basis which could result in Orders to Cease and treatment plant, an occasional failure to meet a specific waste discharge requirements was Desist with a time schedule for correction, or merely dismissed on the basis of being a minor Also as noted earlier, during the years of successful operation of the District's wastewater

of formal enforcement actions. requirements which were viewed by the RWQCB as being minor and correctable in the absence 2001 there have been a number of minor deviations from meeting of waste discharge Since initial operation of the District's wastewater treatment plant in 1965 and until January of

respect to amount of monetary fines to be given to the offending discharger by the State Water mitigating factors. The discretion applicable to enforcement is now being primarily seen in discretion as to the real significance to water quality impairment of the receiving waters or other mandatory monetary fines for any violation of waste discharge requirements with very little However, the State of California legislature in January of 2001addopted a new law imposing Resources Control Board.

the time of the several District treatment plant improvements, these improvements have redundancy has been seen as having available both a centrifuge and sludge drying beds, either complete facility duplication. Among those expedients, for instance would be the availability and use of chemical flocculants to enhance settling of solids and associated BOD through a primary units being able to meet needs for short periods of time independently. included designing availability of two primary clarifiers and two sludge digesters, either process one or the other being capable of meeting sludge drying needs at least in the short-term. During normal ability adequately remove solids. During the early history of the District's treatment plant clarifier when one clarifier is taken out of operation and another is otherwise overloaded beyond practical view there are other less costly expedients that can be included to limit costs for having two, identical wastewater treatment plants alongside of each other. However, in a standards as well. It is seen that, in a literal sense this redundancy need could only be met by needed for repairs or replacement. This redundancy need has added weight from Federal EPA requirements even during periods of normally anticipated individual process unit shut-down The foregoing speaks to the issue of redundancy, the added significance to having wastewater treatment plant facilities with sufficient redundancy and flexibility to meet discharge

redundancy specifically now existing in respect to having available only a single fixed film matter is seen in further detail in the K/J 2005 report which reveals the essential lack of unit redundancy are to be seen and were recognized and alternatives studied. This subject As a result of the referenced K/J 2005 study and report, the now more critical needs for process

with a new secondary clarifier, both of which process units are concurrently needed to meet respect to redundancy. more recently added demands of the more restrictive waste discharge requirements and also in requirements was an important part of the recommended improvement project. The recommended project includes construction of a new activated sludge aeration system along study. As revealed, the study of alternatives and possible expedients to meet redundancy Recognizing that these two major process units lack redundancy in case of any extended need to take one process unit operation was a primary focus as seen in the K/J 2005 engineering units out of operation, could prejudice uninterrupted meeting of waste discharge requirements. reactor (FFR) and a single secondary clarifier. Either of these two major and necessary process

It is concluded that the understandings regarding Changed Regulatory Agency Enforcement Policies as discussed in the K/J 2005 study are appropriate to the design of the proposed wastewater treatment plant improvement project.

# Review of Changes Affecting Financing

additional separate document. financing is based on the summary of revised estimate of total project costs also provided in an project are to be seen in detail in separate document prepared by others. The proposed plan for Review of needed financing of the recommended wastewater treatment plant improvements

which will also result in project financing on a relatively less cost basis to the benefit of District seen in the design of the currently recommended wastewater treatment plant improvements discharge requirements along with changes in the District's wastewater characteristics. These current population needs, but also needs associated with then unpredictable changes in waste constituency. changed needs have occurred and have resulted in lower costs. These factors are all to be sequenced projects have resulted in ability to accommodate and build facilities expeditiously as wastewater treatment improvement projects were performed to meet not only substantially lower projected year 2020 service area population to be 115,000. Instead, a series of District treatment and disposal facilities associated with the then local and county planning agencies extreme example of asking the District's sewer users in 1965 to finance the wastewater probably even more significance however can be demonstrated by contemplating the most past nearly 50 years since the South San Luis Obispo County Sanitation District was formed. Of financing has resulted in significant savings in charges to the constituents served during the providing needed wastewater treatment plant improvements on an anticipated relatively short range time frame has allowed a "pay-as-you-go," program of financing. It can be seen this It is to be observed, as previously mentioned, that the historic policy of the District Board of

that the size, scope and costs of the now proposed project has required a thorough assessment While the "pay-as-you-go" financing has been appropriate and beneficial in the past, it is noted independent counsel with the same objective of minimizing necessary costs to the District's rate of alternatives for financing. This assessment along with recommendations has been done by

same lest cost goals in the interests of District rate payers. been studied and is recommended by independent financing experts to accomplish the standpoint of the rate payers. The now proposed financing of the current project has improvements in the past on a "pay-as-you-go" basis has been highly beneficial from the It is observed that in respect to financing the series of wastewater treatment plant

# 1.8 Review of Peer Review Report

under the date of February 8, 2010. then provided the District with their Peer Review report which was submitted to the District was authorized to hire the firm of Carollo Engineers to conduct the review. Carollo Engineers "Peer Review" of the K/J 2005 report and recommendations. Accordingly, the District Engineer significant scope and estimated costs of the recommended project, it was felt wise to have a recommending the next needed wastewater treatment plant improvement project. In view of the As noted it was in 2005, Kennedy/Jenks Consultants submitted to the District their report

an additional (3rd) activated sludge aeration tankage to take the place of the to be abandoned fixed film reactor. K/J Consultants was then asked to review the Peer study recommendations Engineer over the date of January/14 a copy of which is appended. and study. This additional K/J study is summarized in a letter report to the interim District existing fixed film reactor (FFR) process unit. Also, the Peer study suggested the construction of recommended improvements with a suggestion to consider immediate abandoning of the final recommendation of the Carollo Engineers Peer Review studies to proceed with the K/J the alternatives to the K/J recommended improvements. This conclusion was supported by the review, it was evident there were no clear advantage(s) which would offset the higher costs of their estimated costs (2009) of the K/J recommended alternative of \$10,320,000. After further objectives. These alternatives were estimated to cost from \$9,826,000 to \$21,523,000 against eight (8) alternatives for making treatment plant improvements to meet the agreed-upon In summary of the Peer Review Report and recommendations, it is seen that study was made of

ahead with the improvements as proposed and as being the best and most economical of the series of alternatives considered. Review of the K/J 2005 study and recommendation, the project now agreed-upon is to move As may be seen from the Kennedy/Jenks Consultants final review of the Carollo Engineers Peer

confirms the appropriate basis for design of the current recommended wastewater It is concluded that the K/J review of the Carollo Engineering Peer Study dated Jan/14 treatment plant improvement project as set forth in the K/J 2005 study.

### 1.9 Summary

background factors constituting the basis for conclusions set forth in the Kennedy/Jenks Consultants, Long Range Plan, Wastewater Treatment Plant Improvements for South San Luis Obispo County Sanitation District." The information provided above, summarizes a further, more detailed review of the several

The separate reviews of all relevant prior studies and documents summarized above are offered as the basis for concluding the appropriateness of going forward with final design of the recommended wastewater treatment plant final design as set forth in the *K/J* 2005 study.

## Section 2: Recommended Improvement Project

as being for 20 years, or until expected build-out of the District's service area. anticipated waste discharge requirements. The time span of the recommended project is stated electrical and pipework. The basic function to be provided by the recommended improvement structures, new aeration tank and new secondary clarifier along with supporting mechanical, seen in the referenced report, the recommended improvement project includes basically two the various alternatives considered for achieving the stated goals and objectives. Also to be Reference is again made to the K/J studies summarized in their 2005 report. This study outlined project, is seen from the perspective of meeting stated necessary goals centered on current and

following summary: The relationship of the recommended improvements project to goals may be seen in the

## 2.1 New Aeration Tank

effluent from the existing fixed film reactor (FFR). The new aeration tank will be designed for the normal sequence of operation to receive the

done successfully in the past. unlikely. In addition, the expedient of adding chemicals for flocculation ahead of the primary clarifiers to reduce both solids and BOD loading on the FFR is entirely practical and has been need for taking both, separate, aeration compartments out of operation concurrently is highly account for the redundancy needs associated with FFR limitations when operating alone. The requirements. One of the reasons for dividing the aeration tank into two compartments is to still a BOD residual of some 51 mg/l when 30 mg/l is necessary to meet waste discharge is out of operation and all secondary treatment must be accomplished by the FFR. As noted above, the FFR operating alone under design loadings is expected to produce an effluent with issue of redundancy, it is anticipated that there might be a rare occasion when the aeration tank report under these conditions, through operating expedients along with somewhat oversized aeration tanks, it is expected that monthly discharge requirements will be met. Regarding the primary clarifiers will need to go directly to the aeration tanks. As discussed in the 2005 K/J of operation for maintenance or other needed repairs, the entire wastewater flow from the that required is as a result of needing to design the aeration tank on the basis of concurrently meeting the process unit redundancy requirement. That is, in the event that the FFR is taken out final effluent residual BOD will be in the range of 20 mg/l. This further reduction of BOD beyond maximum of 30 mg/l or an additional 42% reduction. In actual operation, it will be expected that purpose of further reducing the FFR residual BOD of 51 mg/l to the waste discharge required residual from the primary clarifiers, from an average expected concentration of 198 mg/l to an expected 51 mg/l, or about 75% reduction. The new aeration tank is fundamentally for the At design loadings, the existing FFR is expected to reduce biochemical oxygen demand (BOD)

objectives relating to, 1) more stringent waste discharge requirements and, 2) process unit It is of special interest to note the unique and less costly means of concurrently meeting the dual

an upstream process upset or unexpected incoming wastewater loadings. also could serve to reduce costs for possible future reclamation and reuse as well guard against meeting waste discharge requirements most of the time, this available higher level of treatment majority of time when both FFR and aeration tank operation is in progress. By more than redundancy requirements, will more than meet BOD/SS requirements during by far the normal, an aeration tank providing a detention time of 2.4 hours, rather than the more typical 4 hours. amount of solids under aeration for assumed limited time periods, than typical, but in this case, advantage of by assuming and providing aeration sufficient to support a significantly higher detention time. As shown in more detail in the K/J 2005 report, this inherent function is taken advantage of the inherent function of activated sludge it is seen that within limits activated sludge treatment results can be achieved by substituting solids under aeration (MLSS) for wastewater flows going from the primary clarifiers directly to the aeration tanks, at normal loadings, aeration tank detention time would need to be in the range of 4 hours. Taking aeration tanks providing a detention time of about 1 hour. However, to meet redundancy needs This compromise strategy allowing for a smaller size and cost aeration tank, while meeting in the event that the up-stream fixed film reactor is out of service and with all partially treated maximum residual BOD/SS = 30 mg/l in plant effluent could easily be met with activated sludge redundancy. The needed improvements to meet the more stringent requirements calling for a

in the K/J 2005 study and report, the new aeration tank as proposed will be adequate to construction of the proposed new aeration tank, as discussed above and further set forth It is concluded after further review of the numerous factors surrounding design and meet the design objectives.

## 2.2 New Secondary Clarifier

incurred by reason of interposing the new aeration tank between the fixed film reactor and secondary claritiers. be some pumping to, or from the secondary clarifiers to account for the added head loss clarifier, both secondary clarifiers being downstream from the aeration tank. There will need to The new secondary clarifier will be designed to operate in parallel with the existing secondary

clarifier, 2) anticipating the most likely need for existing secondary clarifier shut-down being solids and associated BOD removals ahead of both the fixed film reactor and new secondary expedients could be 1) use of chemical flocculants ahead of the primary clarifiers for higher seems highly unlikely to occur, expedients which could be practiced as the alternative to standards when operating over a sustained period of time. While this most extreme condition loading conditions, when the existing secondary clarifier is out of operation at a time of peak that potential hydraulic loading on the new secondary clarifier under the most extreme possible clarifier for short periods of time, and 3) utilizing the way in which the waste discharge replacement or repairs needed, one of the two existing primary clarifiers has existing pipework to act as a back-up secondary clarifier and could be operated in parallel with the new secondary building a much larger secondary clarifier with much higher costs, could be anticipated. These winter time storm water flow conditions, the overflow rate and detention time would not meet secondary clarifier and in particular under normal loading conditions. However, it must be noted The design criteria revealed in the K/J 2005 report continue to be appropriate for the new requirements are written in respect to monthly, seven-day and one-day maximum allowable

for the month with the seven day window, would be 24 mg/l, well below the 30-day requirement. on sustained dry-weather flow basis will be to produce a plant effluent of 20 mg/l, the average suspended solids call for a maxim allowable limit on a 30-day basis of 30 mg/l. The allowable limit for a 7-day period is 60 mg/l. If it is assumed that the improved treatment plant capabilities concentrations. For instance, the waste discharge requirements in respect to BOD and

occurring. might then be scheduled to occur during times of the year other than when storm flow might be clarifier would be need for replacement of the existing mechanism. The work of replacement The most likely scenario which might involve taking out of operation the existing secondary

combinations of extreme conditions. suggests looking to expedients as noted above as the method of handling the most unlikely clarifier mechanisms such as in this case, have an exceptional history of reliability which prolonged period of winter time maximum flow conditions seems most unlikely to occur. Circular The possibilities of some mechanical failure of the existing secondary clarifier occurring during a

secondary clarifier of the wastewater treatment plant improvements project. report confirms the appropriate basis for design of the recommended aeration tank and It is concluded that the further review summarized above and the K/J 2005 study and

### Section 3: Recommended Project **Engineer's Opinion of the Probable Cost of** Construction and Operation and Maintenance of

associated yard piping, FFR effluent pump station, Aeration Blowers, new secondary clarifier, WAS thickening and sludge dewatering. The updated opinion of the probable cost of the project is \$12,061,000 and the estimated annual operations and maintenance costs are \$363,000 per engineer's opinion of the probable cost of construction of the recommended project and the are included with this report. year. Spreadsheets with a breakdown of the estimated quantities and costs for these opinions operations and maintenance costs. The recommended project includes new aeration tanks, As part of this effort to review the prior documents, we have prepared updated estimates of the

### Appendix A: Comments on K/J Recommended Improvement Project vs Carollo

South San Louis Obispo County Sanitation District Studies

#### Introduction

District. The recommendations set forth in this report centered on the need to improve existing secondary treatment works for the purpose of, 1) insuring meeting of more restrictive waste secondary treatment process units. discharge requirements and 2) redundancy in the event of possible shutdown of major Under the date of July 2005, Kennedy/Jenks Consultants (K/J) presented a report, "Long-Range Plan – Wastewater Treatment Plant Improvements" to South San Luis Obispo County Sanitation

indicated a combination of factors favoring the dual process alternative, both economic as well To meet these two needs, K/J compared two alternatives, 1) addition of a second fixed film reactor to the existing FFR and, 2) continued use of existing FFR along with addition of an as operating reliability. activated sludge (AS) unit providing a dual process. The comparison shown in the K/J report

SSLOCSD in a document under the date of February 9, 2010. A "Peer Review" of the K/J report was undertaken by Carollo Engineers and presented to the

project with continued use of the existing FFR. would meet the same level of secondary treatment as would the K/J recommended single stage system of snail removal. Finally, the two phase Carollo recommended alternative was assumed date, suggested to be 2016. In addition, it was suggested that there would need to be a costly recommendation was based on an assumption that if the FFR was to be kept in operation as the first stage of the dual process alternative, the FFR media would need to be replaced at an early abandonment of the existing FFR process unit and adding a third AS aeration basin. This aeration tanks and a new secondary clarifier, to be followed with a second phase resulting in project would basically provide the same elements recommended as the K/J, two new AS a two-phase improvement project instead of one project now. The recommended first phase with a recommendation to extend the dual process as shown in the K/J report, but to plan on for The Carollo Peer Review study evaluated additional alternatives to be considered, concluding

project comparisons in respect to meeting of requirements as well as process stability and assumed early (2016) costly replacement of the existing FFR media and attendant costly snail removal facilities. The Carollo recommended project did not include an evaluation of alternative somewhat less costly than the recommended K/J program, with cost factors based on an operating costs including energy. The two-phase Carollo recommended two-stage rogram of improvements was shown to be

need to be replaced at possibly some early future date. whether to include abandoning the existing FFR, or accept the possibility that the media would recommended K//J project should be implemented, then there would need to be a decision appropriate to move forward at this time to construct a single project not a two phase project now followed by a second project soon thereafter. On the other hand, if it is agreed that the the present, from a financing and construction standpoint, our opinion is that it would be more Given the foregoing, it is evident that accepting the basic assumptions supporting the Carollo recommended two-phase project, and the time lapse since both the K/J and Carollo reports to

recommended K/J and Carollo alternative projects. In view of the relatively close project cost estimated by Carollo between the two alternatives. it is considered advisable to give further consideration as to the assumptions surrounding both the

### **Basic Assumptions Reviewed**

The proposed K/J alternative for meeting the combined needs of 1) assuring a continuous meeting of an effluent minimum requirement = 30 mg/day and 2) provide redundancy in the event that the FFR is out of operation for short period of repair, calls for two AS aeration tanks, with total volume of 0.52 mg = 69,333 cf. Design basis is for 4.2 mgd average design flow, and BOD going to the proposed two activated sludge aeration tanks with total of 0.52 mgd volume = BOD of 330 mg/l with removal through the primary clarifiers leaving 174 mg/l or, 6,094/day lbs of BOD to the FFR. It is shown that BOD removed through the FFR results in 1,776 lbs/day of

This results in a BOD loading of the aeration tanks of 1,776/69 = 26 lbs BOD/1,000 cf/day

basic design basis, the total BOD loading to the aeration tanks under the Carollo alternative in the absence of the FFR, then would be: assumes the FFR is abandoned so that the entire 4.2 mgd from the primary clarifiers goes directly to three AS aeration tanks with a total volume of 0.89 mg = 119,000 cf. On the same The proposed Carollo alternative for meeting the same defined needs as defined above.

6,094/119 = 51 lbs BOD/1,000 cf/day

twice the BOD AS aeration tank loading than under the K/J alternative with the FFR and two AS 330 mg/l, the recommended Carollo alternative AS aeration tank(s) loading would be 51/26, or Thus, under the assumed continuous loading of the projected 4.2 mgd with incoming BOD of aeration tanks operating.

the same defined needs for BOD reduction, the proposed Carollo alternative, the total volume of aeration tanks would need to be: loading basis of the proposed K/J improvements with FFR and AS aeration tanks and meeting lbs/1,000 cf/day in the absence of the FFR as recommended by Carollo, and on the same To operate on a continuous loading to the AS aeration tanks resulting in the BOD loading of 51

entire 4.2 mgd design flows contain a total of 234,000/3 = 39,600 cf each; whence, number of 6,094/26 = 234,000 cf Each of the three aeration tanks proposed by Carollo for treating the

by K/J would need to be: the same size tanks under the same loading proposed for the dual process alternative proposed

234,000/39,600 = 6 aeration tanks, not the 3 proposed

the K/J alternative. The cost comparison would then significantly favor the K/J alternative results, it would require six aeration tanks with the Carollo alternative, two aeration tanks with loading. Or another comparison would be to achieve the same total secondary treatment recommended project utilizing the FFR to remove 50% of the BOD loading ahead of the aeration tanks, results in AS loading to be one-half the proposed Carollo AS aeration tank would be difficult to speculate. What is clear is that using conventional activated sludge, the K/J The different final, end results in terms of effluent discharged to the ocean under the proposed K/J dual process AS aeration tank versus the proposed Carollo BOD loading two times as high

identified in their report as Alternative No. 4B to be constructed in two phases. The total estimated cost of this alternative is \$ 9.826,000. The Carollo alternative for conventional activated sludge secondary wastewater treatment is

total Carollo estimate of this K/J alternative is \$ 10,607,000. interpreted in the Carollo report is shown as Alternative 4A to be constructed in two phases. The The K/J alternative for combined fixed film reactor and conventional activated sludge as

figures for aeration tanks as shown in the Carollo Alternative 4A and 4B reports, the total Carollo alternative then would be in the range of \$ 13,000,000. than recommended by Carollo, or a total of six aeration tanks, not three. Using the same cost removal, the Carollo recommended Alternative 4B would require three more, aeration tanks, However, the analysis set forth above, in order to achieve the same results in terms of BOD

by Carollo, of \$ 10,607,000. Not the \$ 9,826,000 Carollo alternative estimate against the proposed K/J alternative estimated

recommended alternative does not include added considerations of: It should be noted also that this now estimated cost difference between the Carollo and K/J

- Significantly higher operating costs of the alternative using AS process only
- Significantly higher energy costs of the alternative using AS process only
- Higher potential for process operation upset with AS alternative using AS process only.
- 0 More stable operation with FFR first stage, especially when encountering unexpected loadings; both volume and biologic which buffers loading variation on the following more
- 0 recommended continuing use of dual process with FFR. This is in respect to both longevity (Carollo estimate 2 years hence)), and costs associated with, "snail removal." Questionable assumptions under the Carollo defined costs associated with the K/J

The question as to continued use of FFR could be seen as mute at this time since Carollo and K/J agree that FFR should be in continued use until needing media replacement; at which time the subject could be re-visited. Every year the FFR continues as the first-stage of existing dual reverse the alternative project costs. quality and process reliability assured (unless four aeration tanks constructed which would process, 1) cost savings of both money interest and energy are realized and 2) better effluent

future adding tankage for a future anoxic stage. case, the aeration tank site location shown in both studies could be altered in anticipation of A remaining question might be in respect to possible future needs for nutrient removals in which

### Additional Observations

FFR only as a result of then continuing problems of maintaining consistent operation with AS, changed waste discharge requirements as well as less costs for FFR. The 1986 expansion FFR alternative also resulted in significantly more reliable process operation. resulted in an overall cost saving on energy of one-half of that required for the original AS. The provided secondary treatment through the use of a conventional activated sludge process only. The major 1986 expansion abandoned the use of AS and provided secondary treatment with It might be noted that the original SSLOCSD wastewater treatment plant, constructed in 1963,

#### Conclusion

revisit the K/J 2005 report as part of a process to re-define the project in some detail and prepare revised estimates of project costs Kennedy/Jenks Consultants report be followed. To proceed at this time it will be necessary to basic project to meet defined wastewater treatment needs as defined in the 2005 Based on the various considerations summarized above, it appears appropriate to conclude the

but probably much longer into the future beyond the suggested year 2016 It would be understood that at some time in the future the FFR media may need to be replaced,

JHJJan./14

## Appendix B: **Opinion of Probable Construction Cost**

OPINION OF PE	ROBABLE CONSTRUCTION COST		KENNEDY/JENKS CONSULTANTS
Project: Re Building, Area:	ecommendation for Upgrading the Existing Wastewater Treatment Plant  South San Luis Obispo County Sanitation District		Prepared By: TTB/NL  Date Prepared: 14-May-14  K/J Proj. No. 1368035*00
Estimate Type:	Conceptual Preliminary (w/o plans) Deskin Development (ii)	Construction Change Order	Current at ENR 10,736 (Jan 2014- Los Ange Escalated to ENR Months to Midpoint of Construct

pec.	Item	Design Development @		% Comp		rials						
ction	No.	Description	Qty	Units	S/Unit	Total	\$/Unit	Itation Total	Sub-c \$/Unit	ontractor Total	Total	Source
		New Activated Sludge Aeration Tank (122' x 36' x 16')										
		Earthwork (Excavation)	7500	CY			40.40	101.000				
		Earthwork - Backfill (Structural Material) & Compaction	3600	LCY	20.85	75.071	16.18	121,365			121,365	2014 RS Means G 1030 120 2200
		Earthwork- Dewatering	3000		20.00	75,071	6.95	25,030			100,100	2014 RS Means 31 23 23.14 3200 & 31 23 23.15 5000 & G1030 210 100
		Reinforced Concrete-Foundation Mat	370	CY			927.95	27,839			27,839	2014 RS Means 31 23 19 20 0800 & 0820
		Reinforced Concrete-Walls	310	CY					1,100	407,407		Typical Historic Costs
		FFR Elfluent Pump Station	310	LS		200,000	-		1,500	474,000		Typical Historic Costs
		Influent Yard pipe (24* HDPE from FFR)	350	LS	43.20	280,000		80,000				Est mate
		Influent RAS Yard pipe (24" HDPE from Existing Secondary Clarifier)		LF		15.118	53.01	18,554				2014 RS Means G3020 112 3050
		Effluent Yard Pipe (30" HDPE to New Secondary Clarifier)	270		43.20	11,663	53.01	14,313			25,975	2014 RS Means G3020 112 3050
			08	LF	64.05	5,124	77.00	6,160			11,284	2014 RS Means G3020 112 4000
		Effluent Yard Pipe (30" HDPE to Valves/Ex Secondary Clarifler)	290	LF	64.05	18,574	77.00	22,331			40,905	2014 RS Means G3020 112 4000
		Demo and reinstalt AC over Trenching for 24* Piping	276	SY	15.10	4,161	53.70	14,798			18,959	2014 RS Means 32 12 16.13 1050and G1020 210 1000
		Demo and reinstall AC over Trenching for 30* Piping	185	SY	15.10	2,794	53.70	9,935			12,728	2014 RS Means 32 12 16.13 1050 and G1020 210 1000
	2	Blowers & Diffusers for Aeration Tanks										
		High Efficiency-Single Stage blowers w/VFDs	3	EA	250,000.00	750.000	100,000.00	300,000			1,050,000	Verbal Quotation from Siemens Rep
		Diffusers - Air Piping, valves, and fittings installation included	1	LS	150,000.00	150,000	74,995.20	74,995			224,995	Verbal Quote From Evoqua & Estimate of installation costs
	3	Blower/Electrical/MCC Building (20'x20'x12')										
		Building Pad	30	CY					1,100	33,000	33,000	Typical Historic Costs
		Storage/Warehouse Building (Unit Costs)	400	SF	40.00	16 000	23.00	9,200			25,200	2014 RS Means 50 17 00 1010 (SF Unit costs for storage buildings)
	4	New Secondary Clarifier (Diameter 87" X Depth 12")										
		Earthwork - Excavation	6,700	BCY			16.18	108,419	2		108,419	2014 RS Means G 1030 120 2200
		Earthwork - Backfill (Structural Material) & Compaction	4,000	LCY	20.85	83.412	6.95	27,811			111,223	2014 RS Means 31 23 23.14 3200 & 31 23 23.15 5000 & G1030 210 10
		Earthwork- Dewatering	30	Day			927.95	27,839			27,839	2014 RS Means 31 23 19:20 0800 & 0820
		Reinforced Concrete-Foundation Mat	500	CY					1,100	550,000	550,000	Typical Historic Costs
		Reinforced Concrete-Walls	250	CY					1,500	375,000		Typical Historic Costs
		Clarifier Drive/Rake Mechanism	87	DIA-FT	1,500.00	130,500	500.00	43,500			174,000	Rule of thumb
		(6) RAS Pumps (5 HP-2.5mgd)	6.00	EA	28,000.00	168,000	10,000.00	60,000				Actual 2013 Cost for similar pumps and installation at LVMWD
		(4) WAS Pumps (130 gpm)	4.00	EA	20,000.00	80.000	10,000,00	40,000			120,000	Fairbanks Morse non-clog, dry-pit solids handling pump (waiting for more
		Piping, valves, fittings, and Appurtenaces (for dry-pit also)	1.00	LS	350,000.00	350,000	120,000.00	120,000			470,000	Estimate
		Influent 30" from seration tank Piping (Accounted for in Section Acve)	1			The second secon					470,000	Local rotto
		Influent Yard Pipe (30" HDPE from valves/Primary Clarifier #2)	270	LF	64.05	17,293	77.00	20,791			38 084	2014 RS Means G3020 112 4000
		Effluent Yard Pipe (30" HDPE to CCT)	425	LF	64.05	27.221	77.00	32,727			50.004	2014 RS Means G3020 112 4000 2014 RS Means G3020 112 4000
		RAS Yard Pipe (24" HDPE to valve heading back to aeration)	160	LF	43.20	6,911	53.01	8,482			15 393	2014 RS Means G3020 112 4000
		WAS Yard Pipe (6"HDPE to Sludge Thickening/Centrifuge)	440	LF	12.16	5,352	14.79	6,506				2014 RS Means G3020 112 1450
		Demo and reinstall AC over Trenching for 30" Piping	348	SY	15.10	5.247	53.70	13,661			00,000	2014 RS Means G3020 112 1450
-		Demo and reinstall AC over Trenching for 24* Piping	71	SY	15.10	1.074	53.70	3,819			23,909	2014 RS Means 32 12 16.13 1050and G1020 210 1000
		Demo and reinstall AC over Trenching for 6" Piping	98	SY	15.10	1,476	53.70	5,251			4,893	2014 RS Means 32 12 16.13 1050 and G1020 210 1000
	5	WAS Sludge Centrifuge Thickening/digested sludge dewatering			10.10	1010	33.10	0,601			6,121	2014 RS Means 32 12 16.13 1050 and G1020 210 1100
		Alfa Laval Equipment- ALDEC G2 75	1	EA	280.000.00	280,000	140,000.00	140,000				
	6a	Dewatered Sludge Handling-Raise/Extend Platform		- CA	250,000,00	200,000	140,000.00	140,000			420,000	Verbal Quote from Vendor
	Ua .	Demolition of Existing Platform (~25x25*x8**)	450.00	CF								
		New Concrete 12" thick elevated slab (30'x30')	33.33				38.13	17,160			17,160	2014 RS Means 02 41 19 16 1050
		Reinforcement		CY	000.00	0.6	0.50.00		2,500.00	83,325	83,325	Typical Historic Costs
		Structural Steel Beams/ Columns	3.00	Ton	993.00	2,979	859 32	2,578				2014 RS Means
			1.00	LS			-		50,000.00	50,000	50,000	
	6b	Setting newequipment	1.00	LS			15,000 00	15,000			15,000	Estimate (One day crane operations)
	60	Dewatered Sludge Handling- Shaftless Conveyor					-				10	
		Design of Conveyor	1.00	LS			-		25,000.00			Estimate
		Shaftless Conveyor	1.00	EA	8,000.00	8.000	2,873.70	2,874	48,000.00		58,874	Quote from KWS Design, Engineering, Manufacturing
		Alfa Laval Diversion Gate	1.00	EA					14,500.00	14,500	14,500	Quote from KWS Design, Engineering, Manufecturing
		Additional Mechanical/Electrical	1.00	LS	10,000.00	10.000	10,000.00	10,000			20,000	
		Misc. Instrumentation and Controls & Electrical Construction	15.00	%					900,320.80		900,321	
	- 8	Painting/Coating/Miscellaneous Construction	7.50	%					450,160.40	450,160	450,160	

#### Assumptions

Top of Tank @ -19.00 (Water El @ -17.00 and Exsting Ground@ El 10.00) Overexcavata to El -8.0 (assur Structural backfill (select granular fill material) and Spreading (4)? Cillaptrague pumps for 8 hours a day (Exchander Rate of 150 CYfnr from above)

-Poundedor mai (redux, form, frietifing included) utilizing 500.00 pt. Heavy Wegh, Redey Mx, Structural Cq 10<sup>4</sup> high walls 10<sup>4</sup> Direk (calcular) to Tagli 13<sup>4</sup> bink assumption for volumes) wint 5,000pci Concrete

24\* HDPE Type S with waterlight gaskets-6' deep Trendring backlift included)
24\* HDPE Type S with waterlight gaskets-6' deep Trendring backlift included)
30\* HDPE Type S with waterlight gaskets-6' deep Trendring backlift included)
30\* HDPE Type S with waterlight gaskets-6' deep Trendring backlift included)
30\* HDPE Type S with waterlight gaskets-6' deep Trendring backlift included)
Demo and replace-4' trick parement over trendrich systems-4' wide trench over length)
Demo and replace-4' trick parement over trendrich (Assumes-4.5' wide trench over length)

(1000 CFM units with control panel) 9" DualAir Fine Bubble Diffusers

Includes site work, masonry, equipment, plumbing, HVAC, and mech/electrical building materials, GVAC

Top of Tank @ 16.25 (Water El @ 16.00 Exating Ground@ El 10.00) Overexcavate to El -6.0 (assume 16' c Assume 1.3 LCY to TCCY (backfill and avanage of 6'deep) & Grandar Structuria material being brought in) (4) 2" Diaphraga pumps for 8 hours a day! (Eccavation Rate of 160 CYTT from above) 5 st., Henry Weight, Rasdy Aks, Sructural Concretenessuming 16' high 16' high valls 15' hick (calculul) 16' high 16' thick assumption for volumes) with 5.000psi Concrete

Used Similar 5HP Centrifugal studge recirculation pumps from Las Virgenes (escalated 25%)

30° HDPE Type S with wateright gaskets-8' deep Trenching backfill included)
30° HDPE Type S with wateright gaskets-6' deep Trenching backfill included)
30° HDPE Type S with wateright gaskets-6' deep Trenching backfill included)
6' HDPE Type S with wateright gaskets-6' deep Trenching backfill included)
6' HDPE Type S with wateright gaskets-6' deep Trenching backfill included)
Demo and replace 4 thick perement over trench (assumes 4' wide trench over length)
Demo and replace 4' thick perement over trench (assumes 4.6' wide brench over length)
Demo and replace 4' thick perement over trench (assumes 4.6' wide brench over length)

Reinforced Concrete Elevated Slab demotition

OPINION OF PR	ROBABLE CONSTRUCTION COST			KENNEDY/JENKS	CONSULTANTS
Project:	Recommendation for Upgrading the Existing Wastewater Treatment Plant			Prepared By:	TTB/NL
				Date Prepared:	14-May-14
Building, Area:	South San Luis Obispo County Sanitation District			K/J Proj. No.:	1368035*00
Estimate Type:	Conceptual  X Preliminary (w/o plans)  Design Development @	Construction Change Order % Complete	Months	Current at ENR Escalated to ENR to Midpoint of Construct	10,736
TEN UO	SUMMARY BY AREA				
ITEM NO.	ITEM DESCRIPTION	MATERIALS	INSTALLATION	SUB-CONTRACTOR	TOTAL
1	New Activated Sludge Aeration Tank (122' x 36' x 16')	412,504.34	340,323.67	881,407.41	1,634,235.42
2	Blowers and Diffusers for New Aeration Tanks	900,000.00	374,995.20		1,274,995.20
3	Blower/Electrical/MCC Building	16,000.00	9,200.00	33,000.00	58,200.00
4	New Secondary Clarifier (Diameter 87' X Depth 12')	876,486.73	523,805.47	925,000.00	2,325,292.20
5	WAS Sludge Centrifuge Thickening/Digested Sludge Dewatering Equipment	280,000.00	140,000.00		420,000.00
6a	Dewatered Sludge Handling-Raise/Extend Platform	2,979.00	34,738.13	133,325.00	171,042.13
6b 7 8	Dewatered Sludge Handling-Shaftless Conveyor Belt Misc. Instrumentation and Controls & Electrical Construction Painting/Coating/Miscellaneous Construction			900,320.80 450,160.40	900,320.80 450,160.40
	Subtotals				
	Division 1 Costs @ 10%	2,487,970.07	1,423,062.47	3,323,213.60	7,234,246.15
	Subtotals (b) 10%	248,797.01	142,306.25	332,321.36	723,424.62
	Taxes - Materials @ 7.50%	2,736,767.08	1,565,368.72	3,655,534.97	7,957,670.77
	Subtotals (2 7.50%)	205,257.53			205,257.53
	Taxes - Labor @	2,942,024.61	1,565,368.72	3,655,534.97	8,162,928.30
	Subtotals	2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2 2			
	Contractor MU for Sub @ 12%	2,942,024.61	1,565,368.72	3,655,534.97	8,162,928.30
	Subtotals	2,942,024.61		438,664.20	438,664.20
	Contractor OH&P @ 15%		1,565,368.72	4,094,199.16	8,601,592.50
	Subtotals 1376	441,303.69	234,805.31		676,109.00
	Estimate Contingency @ 25%	3,383,328.30	1,800,174.03	4,094,199.16	9,277,701.50
	Subtotal 25%				2,319,425.37
	Escalate to Midpt of Const. @ 2%				11,597,126.87
	Estimated Bid Price	-			463,885.07
	Total Estimate of Project Cost				12,061,011.94
	Total Estimate of Floject Cost				12,061,020.00

Estimate A	ccuracy
+50%	-30%

Estima	ted Range of Probable C	ost
+50%	Total Est.	-30%
\$18,091,530	\$12,061,020	\$8,442,714

OPINION OF I	ROBAE	BLE CONSTRUCTION COST (Operations and Maintenance)							KENNE	DYJENKS CO	INSULTANTS		
Project:		endation for Upgrading the Existing Wastewater Treatment Plant	****						Da	Prepared By: _ ite Prepared: _	TTB 16-Jun-14		
Building, Area:		South San Luis Obispo County Sanitation District							1	KIJ Proj. No	1388035*00		
Estimate Type	X	Conceptual Preliminary (w/o plans) Design Development @		Construe Change	Order			Month	Esca	irrent at ENR_ lated to ENR_ of Construct_		(Jan 2014- Los Angeles)	
Spec.	Item	Description	Qty	Units	Materials/Con-	sumables Total	Lab \$/Unit	or Total	Sub-ce \$/Unit	ontractor Total	Total	Source	Assumptions
Section	No.	Description	uty	Unito	9101111	1000	410mil	70111	- Promit	1010	TOTAL		Assumptions
		Activated Sludge Aeration Tank		-									
		High Efficiency-Single Stage blowers w/VFDs -Power Cost	1	Year	195,406.85	195,407	-				195.407	2 100HP blowers in operation 24/7 (1 unit on Standby). Electricity @ \$0.15/kV	I Vahr
		FFR Eff Pump Station	1	Year	50,531,44	50.581						Assume 2 pumps in operation 24/7 (1 unit on standby)	
	2	Blower/Electrical/MCC Building (20'x20'x12')											
		Building Power Consumption	1	Year	1,000.00	1,000					1,000		
		Cleaning/Maintenance	1	Year	500.00	500					500		
	3	New Secondary Clarifier & Appurtenances											
		Clarifier Drive/Rake Machanism (.5HP Motor)	1	Year	358.44	358					358		
		(6) RAS Pumps (5 HP-2.5mgd) Power Costs	1	Year	19,498.75	19,499						Assume4 pumps in operation 24/7 (2 pumps standby). Electricity @ \$0.15/kV	V-hr
		(4) WAS Pumps (130 gpm-1HP max). Power Costs	1	Year	346.32	346					346	Assume 2 WAS pumps operating 5 hours per day, 6 days per week (70% efficiency). Electricity @ \$0.15&W-hr	
	4	WAS Sludge Centrifuge Thickening/digested sludge dewatering											i e
		Alfa Laval Equipment- ALDEC G2 75 - Energy Consumption	1	Year	3,510.00	3,510					3,510	Assuming 5 hours of operation per day (6 days a week)	
		Cleaning/Maintenance	1	Year	600.00	500							
	5a	Dewatered Sludge Handling- Raise/Extend Platform											
		Trucking to Downtering Beds - Diesel Fuel	20	Gal/Wk	203.00	4.160					4,160	2014 RS Means 02 41 19:16 1050	Reinforced Concrete Elevated Stab demolition
	5b	Dewatered Sludge Handling- Shaftless Conveyor											
		Shaftless Conveyor - Energy Consumption	1	Year	3,510.00	3,510						15HP shaft conveyor from KWS Design, Engineering, Manufacturing	
		Cleaning/Maintenance	1	Year	500.00	500					500		
	6	Misc. Instrumentation and Controls & Electrical Repairs	1	Year	1,000.00	1,000			2,500.00	2,500		Allowance per year to have an outside consultant/mfq	
	7	Painting/Coating/Miscellaneous Construction -Repairs	1	Year	5,000.00	5,000					5,000		
	8	Additional Plant Employee (full-time)	2,080	hr			36.00	74,880			74,880	Includes Fringe	-
Subtotals				1		285.872		74,880		2,500	362,752		1

O&M Estimate Accuracy +50% -30%

Estimated Range of Probable O&M Cost +50% Total Eat. -30% \$544,128 \$362,752 \$253,926



### SOUTH SAN LUIS OBISPO COUNTY SANITATION DISTRICT

Post Office Box 339 Oceano, California 93475-0339 1600 Aloha Oceano, California 93445-9735 Telephone (805) 489-6666 FAX (805) 489-2765 www.sslocsd.org

Staff Report

To: Board of Directors

From: Richard Sweet, PE, District Manager

Date: May 20, 2015

Subject: RECYCLED WATER PLANNING STUDY; STATUS REPORT

### RECOMMENDATION:

That the Board receive the report, discuss issues and provide direction

### BACKGROUND

of the public. At the Board meeting of October 1, 2014 a Recycled Water Project was discussed There were comments of support from the Surf Rider representative and other members

water to the Northern Cities Management Area (NCMA). System Consulting (WSC), the Northern Cities Management Area Engineer, for preparation of a Planning Study for a Recycled Water Project to provide supplemental At the November 5, 2014 Board meeting, the Board approved an agreement with Water

serves most of Arroyo Grande. The concept being evaluated is a satellite treatment facility on the sewer trunk line that The advantages of this concept are:

- face significant opposition. The proposed location is outside the Coastal Zone and the jurisdiction of the Coastal Commission. Expansion of the SSLOCSD plant in the Coastal Zone could
- N piping. This is a significant cost savings over many other alternatives The proposed location would provide opportunities for groundwater recharge landscape irrigation and agriculture irrigation water with very little distribution
- W percolation of the effluent The proposed location is in an area where the groundwater would benefit from
- 4 Brine generated through the satellite treatment plant can be discharged through

the existing trunk sewer line for eventual discharge at the SSLOCSD ocean discharge line.

- S Project may satisfy redundancy requirement for SSLOCSD
- 0 The project is eligible for a planning grant: 50% local match
- take advantage of this funding opportunity. With the water bond approved last November and with significant grant opportunities for recycled water projects in the water bond, timing is excellent to

terminated and no further expenses will be incurred. the District determines that the project is not economically feasible the study will be work within the study will consist of the development of an economic feasibility study. Arroyo Grande has agreed to contribute fifty percent of the local match (\$40,850) and, the Board approved the District's contribution of the remaining fifty percent. The initial the grant and a fifty percent local match comes from local revenue sources. The total local revenue sources required would be \$81,700 (1/2X\$150,000 + \$6,700). The City of percent) for preparation of the planning study will be derived from the planning grant. \$150,000 for preparation of the planning study. Seventy five thousand dollars (fifty The cost of the services within the proposal are \$6,700 for the grant preparation and The planning grant requires a fifty percent match. Therefore \$6,700 for preparation of

application, Attachment "A", details the scope of the work and project timeline submittal of a grant application for preparation of a planning study. The grant At the Board Meeting of February 4, 2015, the Board reviewed and approved the

agreement before proceeding with the work. through the grant. work completed prior to full execution of the grant agreement will be reimbursable assured the District that the District will be receiving a grant agreement shortly. No of the grant application, the SWB will provide a grant agreement to the District, which will be subsequently considered by the Board. The representative of the SWB has District responded to the last question during the week of April 27, 2015. District has responded to a number of questions from the SWB and was notified that the The State Water Board (SWB) is presently reviewing the District's application. The Therefore WSC has been directed to await approval of the grant Upon approval

### DISCUSSION:

insight as to what the District might foresee as insight and conclusions. Pismo Beach study is attached as Attachment "B." approximately one year. The study was also prepared by WSC and provides some the Recycled Water Planning Study appears to lag that of Pismo Beach by recommended alternatives evaluated within the study. The District's effort to complete Facility Planning Study and directed staff to proceed with the implementation of the On April 21, 2015 the City of Pismo Beach City Council approved a Recycle Water The body of the

The Pismo Beach study considered four alternatives:

- 0 Alternative 1: Providing recycled water (RW) at Disinfected Secondary-23 standards for restricted reuse
- 0 Alternative 2: Providing RW at Disinfected Tertiary standards for unrestricted landscape irrigation
- 0 for injection as a coastal seawater intrusion barrier Alternative 3a: Providing RW that meets the standards for groundwater recharge
- 0 for injection directly into the inland aquifer Alternative 3b: Providing RW that meets the standards for groundwater recharge

of these alternatives to utilize a majority of the available water. possibility to utilize the recycled water for direct commercial agriculture use. is available to the District that may not be as readily available to Pismo Beach is the These are similar alternatives to that that the District is evaluating. Alternatives 3a and 3b have been identified as the preferred alternatives due the ability An alternative that

for commercial agriculture. treatment required by Pismo's preferred alternatives may be reduced by the use of RW piping RW to recharge locations identified in the Pismo study are significant. this does provide some insight into the value of the District proposal. The costs of District from similar efforts is not possible with the information available at this time but To try to compare costs of the Pismo preferred alternatives to anticipated costs of the District's satellite plant concept seeks to reduce the cost of piping. The high level of The

proposal will likely exceed that in Pismo's proposal. location other than an existing facility, the cost to provide treatment in the District's Since the District's proposal requires the construction of a new treatment facility in a

significantly different from that proposed in the Pismo proposal. Pismo proposal, with anticipated growth, exceeds the amount of RW in the District The amount of RW available from the District's proposal in the near term is not In the long term the

minimum flows would be an issue. When the use agreement was entered into with Pismo Beach it was not anticipated that require a minimum amount of discharge. The Pismo proposal notes that brine discharge can be accomplished through use of the District's ocean outfall line and that the agreement for the use of the outfall line does not and that a new agreement may be warranted. 1 million gallons a day (MGD) to ensure functional operation of the discharge line It may be argued that this is a change of condition The discharge line requires a daily outflow of

The projected cost of the Pismo Beach project is approximately \$30 million (\$27 million to \$29.7 million) with an annual operation cost of approximately \$600,000. The financing plan for the project as stated in Pismo's report is:

"It is anticipated that the project will be funded through a combination of grants, low

supply." anticipated to be secured through water rates since the project benefits potable water interest loans and cost-sharing contributions from partner agencies. The loans are

support the City of Pismo Beach's recycled water project and direct staff to return with part of Pismo's effort to secure "cost sharing contributions from partner agencies." an inter-agency partnership agreement for Board consideration. It appears that this is At its meeting of May 13, 2015 the Oceano Community Services District voted to

avoid costly litigation. that agencies can reach agreements to arrive at balanced conditions in the basin and undelivered but allocated State Water supply. Groundwater Management Areas. A discussion that will invariably arise will be water supply discussions and contentious discussions between Santa Maria leading to possible salt-water intrusion. This discussion is facilitating supplemental There is much discussion regarding possible over drafting of the NCMA groundwater In this year of extreme drought, water supply is an arena of heightened discussion. While litigation is a possibility, it is hoped

Richard G. Sweet, PE District Manager

Attachments: Attachment "A" Recycled Water Planning Study Grant Application Attachment "B" Pismo Beach Recycled Water Study, body only

# California State Water Resources Control Board Division of Financial Assistance Office of Water Recycling

# Water Recycling Facilities Planning Grant Application

Agency's Federal I.D. No.:	Date: A
Printed Name:	Signature: F
ng all attachments, is true and correct to the odated information will be required to be	I certify that the information in this application, including all attachments, is true and correct to the best of my knowledge and belief. I understand that updated information will be required to be submitted later.
resentative	E. Certification and Signature of Authorized Representative
governing body authorizing the application and ities Planning Grant Program. A model as Attachment 1.)	Submit a certified copy of a resolution adopted by the governing body authorizing the application and acceptance of a grant from the Water Recycling Facilities Planning Grant Program. A model resolution is provided for your reference. (Label this as Attachment 1.)
	D. Authorization
7 to cover 50% of the remaining study cost.	The City of Arroyo Grande will be contributing \$40,877 to cover 50% of the remaining study cost.
s, grants, or other financial assistance being	Other Financial Assistance: Describe any other loans, grants, or other financial assistance being
ursements. Does the Agency have local funds Yes □ No	for the entire study cost, pending receipt of grant disbursements. Does the Agency have local funds on hand to cover the entire estimated study cost?   Output  Description of the entire study cost on hand to cover the entire estimated study cost?  Description on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on hand to cover the entire estimated study cost on the entire estimated study cost on hand to cover the entire estimated study cost on the entire estimated study cost of estimated study cost on the entire estimated study cost on the entire estimated study cost of es
d to have funds available to handle cash flow	Funds for Cash Flow: The grant applicant is expected to have funds available to handle cash flow
study cost up to a maximum grant of	The maximum grant is 50 percent of the total eligible study cost up to a maximum grant of
	2. Requested Grant Amount: \$74,849
	1. Total Study Cost: \$149,896
	C. Facilities Planning Study Information
ared according to the directions in the Water as Attachment 2.)	4. Plan of Study: Please submit a plan of study prepared according to the directions in the Water Recycling Funding Guidelines, Part Two. (Label this as Attachment 2.)
September 2015 December 2015	<ul> <li>a. Study starting date: April 2015</li> <li>b. Submittal of draft facilities plan: Sept</li> <li>c. Submittal of final facilities plan: Dece</li> </ul>
	3. Estimated Project Schedule:
Central Coast Region	2. Regional Water Quality Control Board:
Satellite Water Resource Recovery Facility	1. Study Title:
,	B. Facilities Planning Study Information
Rick Sweet/ General Manager/(805)489-6666	Contact Person (Name/Title/Phone)
Rick Sweet/ General Manager/(805)489-6666	Authorized Representative (Name/Title/Phone):
P.O. Box 339, Oceano CA 93475	Mailing Address:
1600 Aloha PI, Oceano CA 93445	Street Address:
South San Luis Obispo County Sanitation District	Agency Name:
	A. Applicant Information

South San Luis Obispo County Sanitation District Recycled Water Facilities Planning Study Attachment 1: Resolution



## South San Luis Obispo County Sanitation District

Recycled Water Facilities Planning Study


Attachment 2: Plan of Study

#### Introduction

will be to evaluate and select a preferred alternative for a Satellite Water Resource Recovery discharged to the ocean. The purpose of the Recycled Water Facilities Planning Study (RWFPS) water supply opportunities, including recovery and reuse of recycled water that is currently years. As a result, the District and the Member Agencies have been evaluating supplemental water supply portfolios has been significantly impacted by drought conditions over the last 9 disinfected secondary effluent, which is discharged to the ocean. Each of the Member Agencies' Oceano Community Services District (Member Agencies). The Oceano Community Services transmission and treatment service for the Cities of Arroyo Grande and Grover Beach and the Member Agencies. water as a supplemental water supply source and improve the water supply reliability for the Facility (SWRRF) or scalping plant within the District's collection system to develop recycled Halcyon communities. The District's Wastewater Treatment Plant (WWTP) currently produces District (OCSD) provides wastewater collection service to the unincorporated Oceano and The South San Luis Obispo County Sanitation District (District) provides wastewater

### Jurisdiction/Service Area

square miles in southwestern San Luis Obispo County. The District collects wastewater from the limits/service areas for the Member Agencies and the location of the District's WWTP to capture and convey wastewater to the District's trunk lines. Figure 1 shows the city Treatment Plant (WWTP). Each of the member agencies operates their own collection systems member agencies through three primary trunk lines that transport it to the District's Wastewater The District is located in the central coast region of California. Its service area includes 165



# Sources of Recycled Water and Existing Facilities

the District. 2.35 MGD. Table 1 below summarizes the current and projected annual wastewater volumes for District was approximately 38,000 persons. In 2014, the average annual flow to the WWTP was Member Agencies and delivered to the District. As of 2010, the total population served by the The source of water for the proposed recycled water system will be wastewater collected by the

Table 1. Current and Projected Recycled Water Supplies from SSLOCSD

	Existing (2014)	g (2014)	Project	Projected (2035)
Potential Recycled Water Supplies	2.35 mgd	2.35 mgd   2,633 afy   3.5 mgd   3,921 afg	3.5 mgd	3,921 afy
Notes:				
1. Wastewater flows and projections come from the 2014 Regional Recycled Water	ne from the	2014 Region	al Recycled	Water
Strategic Plan		<b>Y</b>		

discharged from the plant through an ocean outfall line. and then to the 665,000 gallon secondary clarifier. After secondary clarification, the wastewater digesters, while the primary effluent is discharged to a trickling filter for secondary treatment gpd/sf under average annual daily flow. Sludge from the primary clarifiers is sent to the clarifiers have a combined volume of 320,625 gallons and a combined overflow rate of 610 is disinfected with sodium hypochlorite in a chlorine contact chamber, de-chlorinated and filter, secondary clarifiers, anaerobic digesters and disinfection contact basin. The primary The WWTP includes an in-channel screen, primary clarifiers, a secondary treatment trickling

new upstream treatment capacity and increased redundancy at the existing WWTP due to process upset. It is envisioned that development of a SWRRF would provide the SSLOCSD with existing trickling filter to be taken out of service for extended maintenance or in the event of a decreased flow rates The WWTP currently lacks sufficient redundancy in its secondary treatment system to allow the

## Anticipated Recycled Water Alternatives

development of a SWRRF and use of recycled water for landscape/agriculture irrigation and/or indirect potable reuse. As part of the preliminary analysis that has been completed in preparation The conceptual SWRRF locations are shown in the Figure 2 and the average flows at these for developing the RWFPS, two conceptual locations for a proposed SWRRF were evaluated The District anticipates developing recycled water as a supplemental supply source through the locations are summarized in Table 2.




Table 2. Average Flows to Conceptual SWRRF Locations

Conceptual SWRRF	Average Flows (gpd)	Average Flows (AFY)
Location		
Alternative 1	0.56	753
Alternative 2	0.82	1,103
Notes:		
I Flow estimates obtained	Flow estimates obtained from the District's Wastewater Collection System Model	ollection System Model

osmosis for agricultural irrigation and advanced treatment for groundwater recharge. alternatives will be evaluated. It is anticipated that the treatment and use alternatives evaluated will include disinfected tertiary for unrestricted irrigation, disinfected tertiary with partial reverse During the development of the RWFPS, multiple SWRRF and recycled water end use

studies will be incorporated into the evaluation of the SWRRF alternatives completion of a RWFPS for its wastewater treatment plant. The relevant findings from these which included an evaluation of recycled water alternatives for the District. The City of Pismo Beach, which is adjacent to the Member Agencies' service areas to the north, is also nearing The County of San Luis Obispo recently completed a Regional Recycled Water Strategic Plan.

Arroyo Grande have identified a few potential alternative supplemental water supply sources. RFWPS and compared against the proposed recycled water alternatives. The findings from these non-recycled water alternative studies will be summarized in the Additionally, several prior studies, including the District's Desalination Funding Study, the Lopez Lake Spillway Raise Project and the Urban Water Management Plan for the City of

alternatives, will then be evaluated to develop a preferred project alternative requirements (e.g. delivery and system pressure, peak delivery and storage criteria, level of treatment, cost basis, etc.). The identified alternatives, along with non-recycled water The alternatives for this RWFPS will be developed using consistent planning and design

### Stakeholder Participation

comply California Recycled Water goals. on water quality, effective groundwater management, and how a water recycling program will and other stakeholders was held by the District in 2012 to address water recycling and its impact and elements and encourage stakeholder input. A Water Recycling Forum with local agriculture The District intends to conduct numerous stakeholder meetings to coordinate project objectives

stakeholder concerns, determine goals and challenges and to develop public support for recycled the RWFPS. The District will conduct meetings and educational workshops with Member water use. A plan to encourage recycled water use for potential customers will be developed to Agencies, local community members and potential recycled water customers to address establish long-term contracts for recycled water applications. The District will continue to encourage stakeholder participation throughout the development of

coordinate and collaborate with stakeholder agencies. project specific meetings, these monthly meetings will provide a venue to continuously Beach meet on a monthly basis to manage their shared water supply resources. Along with In addition, representatives from each of the District's Member Agencies and the City of Pismo

#### **Potential Problems**

these problems are shown in the table below. Potential problems that could delay progress of the RWFPS and proposed actions to mitigate

Table 3. Potential Problems and Mitigating Actions for the RWFPS

Potential Problem	Mitigating Action
Loss of Funding	The RWFPS is anticipated to be funded by three agencies, including
	the State Water Resources Control Board (SWRCB). This reduces the
	burden on each of the agencies and reduces risk of funding loss.
Multi-Agency	Numerous stakeholder, public outreach and project team meetings are
Coordination	included in the proposed scope of work to assist in building consensus
	and agency buy-in.
Limited Data	Several recycled water planning studies have recently been completed
	on District and neighboring facilities that will provide extensive data
	for use in completing the SWRRF RWFPS. Additionally, ongoing
	investigations to characterize the regions hydrogeology will assist in
	evaluating opportunities for recycled water groundwater recharge.

## Entities Conducting the Study

of the Santa Maria Groundwater Basin that could be recharged with recycled water from the development of the San Luis Obispo County's Regional Recycled Water Strategic Plan. Additionally, WSC is on the steering committee for an ongoing study to characterize the portion is currently completing a RWFPS for the City of Pismo Beach and participated in the The District has selected Water Systems Consulting, Inc. (WSC) to complete the RWFSP. WSC

upon previous work and meets the needs of the District and its Member Agencies. Additionally, work with permitting and resource agencies to develop an implementation plan. District staff will continue to work closely with WSC to better define the alternatives and to Agencies to utilize all available existing reports and studies to ensure that the RWFPS builds District Staff will work closely with WSC and representatives from the District's Member

#### Budget

impact on its rate payers, the District is looking to leverage its available funding by obtaining a with Water Systems Consulting, Inc. as Attachment A to this Plan of Study. To reduce the A detailed scope of work and budget for the RWFPS is included as part of the District's contract

amongst the three funding sources. matching costs with the City of Arroyo Grande. Table 4 outlines the proposed cost sharing \$75,000 grant from the SWRCB Water Recycling Funding Program and by splitting the local

Table 4. Summary of Project Costs

\$156,700	Total Agency Cost Share
\$75,000	RWFPS Grant
\$40,877	City of Arroyo Grande
\$40,877	District
Cost Share	Agency
Project Cost Share for Participating Agencies	Project Cost Share for
\$156,700	Total Cost
\$149,896	Recycled Water Facilities Planning Study
\$6,806	RWFPS Grant Application
Project Cost	Scope of Work Element
Project Cost Summary	Project Co

completing the RWFPS prior to being reimbursed through the SWRCB Water Recycled Funding Both the District and the City of Arroyo Grande possess sufficient reserves to cover the costs of

#### Schedule

more detailed schedule is included as Attachment B. The following table summarizes the proposed schedule for the completion of the RWFPS. A

Table 5. Proposed Project Schedule

December 2015	Submittal of Final Report
September 2015	Submittal of Draft Report
August 2015	Facilities Planning Study
End Date	Scope of Work Element

#### SOUTH SAN LUIS OBISPO COUNTY SANITATION DISTRICT Oceano, CA 93445 1600 Aloha Place

### PLANNING STUDY FOR SATELLITE TREATMENT FACILITY FOR RECYCLED WATER PROJECT

Project Location: South San Luis Obispo County Sanitation District

San Luis Obispo County Sanitation District, a county sanitation district duly existing and operating pursuant to the provisions of Health and Safety Code §4700 et seq. (hereinafter referred to as "SSLOCSD"), and Water Systems Consulting, Inc. (herein referred to as "WSC" or "Consultant"), a California corporation, P.O. Box 4255, San Luis Obispo, California 93404, wherein Consultant agrees to provide the SSLOCSD and SSLOCSD agrees to accept the services specified herein. THIS AGREEMENT (hereinafter referred to as "Agreement") is made by and between the South

the parties agree as follows: NOW, THEREFORE, in consideration of the mutual covenants and conditions contained herein

- Jeff Szytel and/or Dan Heimel, (805) 457-8833 are the authorized representatives for Consultant. Changes in designated representatives shall be made only after advance written notices to the representatives of SSLOCSD and will administer this Agreement for and on behalf of SSLOCSD 1. **DESIGNATED REPRESENTATIVES**. Richard G. Sweet, General Manager and/or John Clemens, Plant Superintendent of SSLOCSD, at telephone number (805) 481-6903 are the
- shall be given to the respective parties in writing, by first-class mail, postage prepaid, or otherwise delivered as follows: NOTICES. Any notice or consent required or permitted to be given under this Agreement

SSLOCSD: South San Luis Obispo County Sanitation District

P.O. Box 339

Oceano, CA 93445 Attn: Richard G. Sweet

Phone: (805) 481-6903

Facsimile: (805) 489-2765

CONSULTANT: Water Systems Consulting, Inc.

P.O. Box 4255 San Luis Obispo, CA 93403

ATTN: Jeff Szytel

Phone: (805) 457-8833 Facsimile: (805) 888-2764

five (5) days following their deposit in the U.S. mail. or at such other address or to such other person that the parties may from time to time designate. Notices and consents under this section, which are sent by mail, shall be deemed to be received

3. ATTACHMENTS. Attached to this Agreement are the following Exhibits. Said Exhibits shall be initiated by Consultant upon request of SSLOCSD or by SSLOCSD directly. Said Exhibits are incorporated herein by reference:

- including a timeline for Project completion. (Exhibit "A") A Description of scope of services (the Project) to be performed by Consultant,
- W Fee Estimate from the Consultant is attached as Exhibit "B"
- C. Consultant shall provide insurance as listed in Exhibit "C"

### 4. SCOPE OF SERVICES.

- technical services of a temporary nature. D SSLOCSD has determined the Project involves performance of professional and
- , ", W Consultant agrees to provide the services to SSLOCSD in accordance with Exhibit
- C. The Consultant shall perform its services in character, sequence and timing so that they will be coordinated with the requirements of SSLOCSD and other consultants of SSLOCSD.
- CI TERM. Consultant shall commence performance immediately.

## COMPENSATION OF CONSULTANT.

- completion of the planning study; and The City of Arroyo Grande has agreed to reimburse the District \$40,877 for
- to pay Consultant for work performed to the date that the economic feasibility study is completed; D. SSLOCSD and Consultant have agreed that Consultant will prepare the grant application and an economic feasibility study prior to completing the Facilities Planning Study and District will determine if the project for a satellite treatment facility is economically feasible. If District determines project is not economic viable, agreement will be terminated. District agrees
- the schedule set forth in Exhibit "B" The Consultant will be paid for services provided to SSLOCSD in accordance with
- with the "Scope of Service" Invoices shall reflect the phase to which the request for payment is being invoiced in accordance Payment of undisputed amounts is due within 60 days of receipt of invoices. (Exhibit "A") and the percentage of completion of each phase
- thousand seven hundred dollars (\$156,700) without written authorization from SSLOCSD Consultant will not receive compensation in excess of one hundred and fifty-six
- materials, supplies, and equipment used in carrying out the services as stated in Exhibit "A" Payment to Consultant shall be considered as full compensation of all personnel,

- to payment will not constitute a waiver of SSLOCSD's right to: SSLOCSD's failure to discover or object to any unsatisfactory work or billing prior
- Require Consultant to correct such work or billings; or
- N Seek any other legal remedy.
- as provided in Exhibit "B". REIMBURSABLE COSTS. Consultant shall be reimbursed at cost for reimbursable costs
- provide a written request for consideration of Additional Services to the SSLOCSD Contract beyond the scope of Basic Services in this Agreement by the Consultant, the Consultant shall Administrator. **EXTRA SERVICES.** Should services be requested by District which are considered to be
- under this agreement, and are not employees, agents or partners of SSLOCSD. contractors, responsible for all methods and means used in performing the Consultant's services INDEPENDENT CONTRACTOR. Consultant, its agents and contractors are independent

## PERFORMANCE STANDARDS

- Compliance with laws
- which become necessary as a result of the Consultant's failure to comply with these requirements, due to failure to meet the Standard of Care, shall be made at the Consultant's expense. and statutes now in force or which may hereafter be in force with regard to the Project and this Agreement. The judgment of any court of competent jurisdiction, or the admission of Consultant in any action or proceeding against Consultant, whether SSLOCSD be a party thereto or not, that Consultant and SSLOCSD. Any corrections to Consultant's instruments of professional service Consultant has violated any such ordinance or statute, shall be conclusive of that fact as between (1) Consultant shall (and shall cause its agents and contractors), at its sole cost and expense, to comply with all District, County, State and Federal ordinances, regulations
- the newly issued requirements at the written direction of SSLOCSD. providing services pursuant to this paragraph shall be submitted to SSLOCSD as Additional Services. requirements. Consultant will bring the instruments of professional service into conformance with preparation, Consultant shall be responsible for notifying SSLOCSD of such Should these requirements change after the date of design or drawing Consultant's costs for change in
- engaged (hereinafter "Standard of Care"). All products of whatsoever nature which Consultant delivers to SSLOCSD pursuant to this Agreement shall conform to the standards of quality and/or licenses shall be obtained and maintained by Consultant without additional compensation normally observed by a person practicing in Consultant's profession. Consultant shall correct or revise any errors or omissions at SSLOCSD's request without additional compensation. Permits standards observed by a competent practitioner of the same profession in which Consultant is and licenses/permits necessary to perform the services required under this Agreement. throughout the term of this Agreement. Accordingly, Consultant shall perform all such services in the manner and according to the Standard of Performance. Consultant represents that it has the skills, expertise

- the services to be performed by Consultant. taxes or assessments now or hereafter in effect and payable by reason of or in connection with federal Social Security Act, any applicable unemployment insurance contributions, Workers Compensation insurance premiums, sales taxes, use taxes, personal property taxes, or other Consultant shall pay all taxes, assessments and premiums under the
- or degree with the performance of services required to be performed under the Agreement. interest and shall not acquire any interest, direct or indirect, which would conflict in any manner such interest shall be employed by Consultant. Consultant further covenants that in the performance of this Agreement, no person having any CONFLICT OF INTEREST. Consultant covenants that Consultant presently has no
- necessary by Consultant in performing the services provided herein. RESPONSIBILITIES OF SSLOCSD. SSLOCSD shall provide all information reasonably
- Project or scope of services contemplated by this Agreement. SSLOCSD's use of documents and instruments of professional service if used for other than the instruments of professional service prepared by Consultant during the performance of this Agreement shall become the property of SSLOCSD. However, Consultant shall not be liable for OWNERSHIP OF DOCUMENTS. All drawings, specifications, data, and other
- records at any time during Consultant's regular business hours or upon reasonable notice accounting practices. SSLOCSD shall have the right to audit and review all such documents and this Agreement. All accounting records shall be kept in accordance with generally accepted pursuant to this Agreement as would be kept by a reasonably prudent practitioner of Consultant's profession and shall maintain such records for at least four (4) years following the termination of RECORDS, AUDIT AND REVIEW. Consultant shall keep such business records

### 16. INDEMNIFICATION

A.1 Indemnification Pertaining to General Liability other than Professional Liability

The following applies to general liability claims other than professional liability claims:

and legal fees, and claims for damages whatsoever, including, but not limited to, those arising officers, agents and employees, except for liability resulting solely from the active negligence or County Sanitation District, the Board of Directors, each member thereof, present and future, or its will apply even in the event of concurrent negligence on the part of the South San Luis Obispo Agreement. It is further agreed, Consultant's obligations to indemnify, defend and hold harmless officers, employees, agents, subcontractors, or vendors in performing services pursuant to this legal fees, arising from the negligent acts or omissions, or willful misconduct of Consultant, its or anyone for whom Consultant is legally responsible. The obligation to indemnify, defend and property loss however the same may be caused by willful misconduct or negligence of Consultant from breach of contract, bodily injury, death, personal injury, property damage, loss of use, or agents and employees from and against any and all liability, expenses, including defense costs Sanitation District, the Board of Directors, each member thereof, present and future, its officers hold harmless includes, but is not limited to, any liability or expense, including defense costs and Consultant shall indemnify, defend, and hold harmless the South San Luis Obispo County

time as a final judgment has been entered adjudicating either the Consultant to be not negligent or the South San Luis Obispo County Sanitation District as solely negligent. negligence of Consultant or that of the sole negligence of the South San Luis Obispo County precedent to enforcement of this indemnity. In the event of any dispute between Consultant and the South San Luis Obispo County Sanitation District, as to whether liability arises from the be obligated to pay for the South San Luis Obispo County Sanitation District' defense until such willful misconduct of the South San Luis Obispo County Sanitation District, its officers, employees Sanitation District or its officers, employees, agents, subcontractors or vendors, Consultant will Payment by the South San Luis Obispo County Sanitation District is not a condition

A.2 Indemnification Pertaining to Professional Liability (Services).

breach of professional performance standards as identified in Section 10 are alleged: The following applies to professional liability claims where professional malpractice or

pursuant to this Agreement officers, employees, agents, subcontractors, or vendors in performing professional the extent caused by the negligent acts or omissions, or willful misconduct of Consultant, its agents and employees from and against any and all liability, expenses, damages whatsoever to Sanitation District, the Board of Directors, each member thereof, present and future, its officers, Consultant shall indemnify and hold harmless the South San Luis Obispo County Services

- any responsibility or liability in contravention of Civil Code §2782 require Consultant to indemnify the South San Luis Obispo County Sanitation District, against Nothing contained in the foregoing indemnity provisions shall be construed to
- as to any claims, so long as the event upon which such claims is predicated shall have occurred prior to the effective date of any such termination or completion and arose out of or was in any employees, agents or consultants, or the employee, agent or consultant of any one of them. way connected with performance or this Agreement shall release Consultant from its obligations referenced in subsection A, above, Neither termination of this Agreement or completion of the Scope of Services under operations under this Agreement by Consultant,
- with the insurance requirements in the Agreement does not relieve Consultant from liability insurance policies shall have been determined to be applicable to any of such damages or claims referenced in subsection A, above. The obligations of this article shall apply whether or not such Submission of insurance certificates or submission of other proof of compliance
- forth in Exhibit "C" INSURANCE. Consultant shall procure and maintain, in insurance companies as set
- required hereunder will be performed by the Consultant or under all personnel required in performing the services under this Agreement. All of the services PERSONNEL. The Consultant represents that it has, or will secure at its own expense,

such services Consultant's supervision, and all personnel engaged in the work shall be qualified to perform

- others providing the same or similar services as those provided by Consultant as the SSLOCSD Agreement and that SSLOCSD shall have the right to negotiate with and enter into contracts with NONEXCLUSIVE AGREEMENT. Consultant understands that this is not an exclusive
- and shall constitute grounds for termination. attempt to so assign or so transfer without such consent shall be void and without legal effect 20. ASSIGNMENT. Consultant shall not assign any of its rights nor transfer any of its obligations under this Agreement without the prior written consent of SSLOCSD and any
- Consultant's reasonable control, Consultant's compensation shall be subject to renegotiation. services performed through the date of temporary suspension. In the event that Consultant's services hereunder are delayed for a period in excess of six (6) months due to causes beyond part of the Consultant to perform any provision of this Agreement. Consultant will be paid for such period as he/she deems necessary due to unfavorable conditions or to the failure on the authority to suspend this Agreement and the services contemplated herein, wholly or in part, for TEMPORARY SUSPENSION. The SSLOCSD's Contract Administrator shall have the

#### 22. TERMINATION.

- date of termination. However, if this Agreement is terminated for fault of Consultant, then SSLOCSD shall be obligated to compensate Consultant only for that portion of Consultant services which are of benefit to SSLOCSD, up to and including the day Consultant receives notice A. Right to terminate. SSLOCSD retains the right to terminate this Agreement for any reason by notifying Consultant in writing thirty (30) days prior to termination. Upon receipt of such notice, Consultant shall promptly cease work and notify SSLOCSD as to the status of its of termination from SSLOCSD performance. SSLOCSD shall pay Consultant for its reasonable costs and expenses through the
- instruments of professional services, whether or not completed, prepared by Consultant, or given for other than the project or scope of services contemplated by this Agreement. SSLOCSD's use of incomplete materials or for SSLOCSD's use of complete documents if used to Consultant in connection with this Agreement. over to the District copies of studies, drawings, mylars, computations, computer models and other Return of materials. Upon such termination, Consultant shall immediately turn Consultant, however, shall not be liable for
- C. Should SSLOCSD fail to pay Consultant undisputed payments set forth in Section 6, above, Consultant may, at Consultant's options, suspend its services or terminate this agreement if such failure is not remedied by SSLOCSD within thirty (30) days of written notice to SSLOCSD of such late payment.
- amount in controversy is less than \$50,000 DISPUTE RESOLUTION. The following procedures apply only to disputes where the
- not settled by mediation, then the parties agree to submit the dispute to binding arbitration as submitted to nonbinding mediation, unless the parties mutually agree otherwise. If the dispute is provided in subsection B, below relating to this Agreement where the amount in controversy is less than \$50,000 shall be SSLOCSD and Consultant agree that disputes between them arising out of or

- of the California Arbitration Act at the time of written demand. The arbitration procedures are as within thirty (30) days from the date of final mediation, in accordance with the prevailing provisions Either party may demand arbitration by filing a written demand with the other party
- refuse or neglect to join in the appointment of the arbitrator(s) or to furnish the arbitrator(s) with (1) The parties may agree on one arbitrator. If they cannot agree on one arbitrator, there shall be three: one named in writing by each of the parties within five days after demand for arbitration is given, and a third chosen by the two appointed. Should either party any papers or information demanded, the arbitrator(s) may proceed ex parte.
- selected. The procedures of the California Arbitration Act are incorporated herein by reference. give each party written notice of the time and place at least sixty (60) days before the date selected by the arbitrator(s). The arbitrator(s) shall select the time and place promptly and shall (2) A hearing on the matter to be arbitrated shall take place before the arbitrator(s) within the County of San Luis Obispo, state of California, at the time and place
- (3) If there is only one arbitrator, his or her decision shall be binding and conclusive on the parties, and if there are three arbitrators, the decision of the two shall be binding in accordance with the prevailing provision of the California Arbitration Act. by any Superior Court having jurisdiction, or that Court may vacate, modify, or correct the award by the arbitrator(s) shall be binding on the parties. A judgment confirming the award may be given and conclusive. The submission of a dispute to the arbitrator(s) and the rendering of a decision
- (4) If three arbitrators are selected, but no two of the three are able to reach an agreement regarding the determination of the dispute, then the matter shall be decided by three new arbitrators who shall be appointed and shall proceed in the same manner, and the process shall be repeated until a decision is agreed on by two of the three arbitrators selected.
- (5) The costs of the arbitration shall be borne by the losing party or shall be borne in such proportions as the arbitrator(s) determine(s).
- liable for payment hereunder to any party other than the Consultant. SSLOCSD NOT OBLIGATED TO THIRD PARTIES. SSLOCSD shall not be obligated or
- may recover its reasonable costs and attorney's fees expended in connection with such an action to this Agreement brought to enforce the terms of this Agreement or arising out of this Agreement COSTS AND ATTORNEY'S FEES. The prevailing party in any action between the parties
- appended hereto, shall be solely for convenience of reference and shall not affect the meaning, construction or effect hereof. SECTION HEADINGS. The headings of the several sections, and any table of contents
- reason be held to be invalid, illegal or unenforceable in any respect, then such provision or be construed as if such invalid, illegal or unenforceable provision had not been contained herein illegality or unenforceability shall not affect any other provision hereof, and this Agreement shall provisions shall be deemed severable from the remaining provisions hereof, and such invalidity SEVERABILITY. If any one or more of the provisions contained herein shall for any

- and in addition to any other remedy given hereunder or now or hereafter existing at law or in or remedies, and each and every such remedy, to the extent permitted by law, shall be cumulative herein conferred upon or reserved to SSLOCSD is intended to be exclusive of any other remedy REMEDIES NOT EXCLUSIVE. Except as provided in Sections 22 and 23, no remedy
- covenant and term is a condition herein. TIME OF PERFORMANCE. Time is of critical importance in this Agreement and each
- often as may be deemed expedient in the sole discretion of SSLOCSD. shall be construed to be a waiver of any such default of an acquiescence therein; and every power and remedy given by this Agreement to SSLOCSD shall be exercised from time to time and as power arising upon the occurrence of any event of default shall impair any such right or power or NO WAIVER OF DEFAULT. No delay or omission of SSLOCSD to exercise any right or
- changed by any oral agreements, course of conduct, waiver or estoppel. right to claim, contest or assert that this Agreement was modified, canceled, superseded, executed by the parties to this Agreement and by no other means. Each party waives their future have been no promises, representations, agreements, warranties or undertakings by any of the parties, either oral or written, of any character or nature hereafter binding except as set forth herein, this Agreement contains the entire understanding and agreement of the parties and there ENTIRE AGREEMENT AND AMENDMENT. In conjunction with the matters considered This Agreement may be altered, amended or modified only by an instrument in writing,
- 32. SUCCESSORS AND ASSIGNS. All representations, covenants and warranties set forth in this Agreement, by or on behalf of, or for the benefit of any or all of the parties hereto, shall be
- 33. CALIFORNIA LAW. This Agreement shall be governed by the laws of the State of California. Any litigation regarding this Agreement or its contents shall be filed in the County of San Luis Obispo, if in state court, or in the federal court nearest to San Luis Obispo County, if in
- together constitute one and the same instrument. and all such counterparts, or as many of them as the parties shall preserve undestroyed, shall counterparts and each of such counterparts shall for all purposes be deemed to be an original; **EXECUTION OF COUNTERPARTS.** This Agreement may be executed in any number of
- obligated, which breach would have a material effect hereon. breached the terms or conditions of any other contract or agreement to which Consultant is Furthermore, by entering into this Agreement, Consultant hereby warrants that it shall not have any state and/or federal law in order to enter into this Agreement have been fully complied with. such entity(ies), person(s), or firm(s) and that all formal requirements necessary or required by and on behalf of any entities, persons, or firms represented or purported to be represented by power and authority to enter into this Agreement in the names, titles, and capacities herein stated AUTHORITY. All parties to this Agreement warrant and represent that they have the
- over those in the numbered sections Agreement and the provisions contained in the Exhibits, the provisions of the Exhibits shall prevail PRECEDENCE. In the event of conflict contained in the numbered sections of this

37. FORCE MAJEURE. Neither party shall hold the other responsible for damages or delays in performance caused by force majeure (acts of nature) or other events beyond the reasonable control of either party.

IN WITNESS WHEREOF, the parties have executed this Agreement to be effective on the date executed by the SSLOCSD.

CONSULTANT

By:

Jéff Szytel

Title: FRS/OAT 1 CEN
Date: 12 / 12 / 14

SOUTH SAN LUIS OBISPO COUNTY SANITATION DISTRICT

By: //////

Richard G. Sweet, General Manager

Date: 12/17/14

Consultant Agreement

### Exhibit A: Detailed Scope of Work

## TASK 1.0 FPGP APPLICATION ASSISTANCE

This scope includes preparing, submitting and managing the FPGP application for the SWRRF project Resources Control Board (SWRCB) for a Satellite Water Resources Recovery Facility (SWRRF) project. the Water Recycling Facilities Planning Grant Program (FPGP) administered by the State Water WSC will assist the South San Luis Obispo County Sanitation District (SSLOCSD) to obtain funding from

## 1.1 FPGP Application Management and Support

- WSC will manage the SWRRF project application through the FPGP process on behalf of SSLOCSD.
- WSC will participate in an initial kickoff call with the SWRCB to start the application development process.
- V forms to complete and submit the FPGP application. WSC will provide ongoing coordination with SSLOCSD to gather required documentation and
- V WSC will coordinate and participate in a meeting with SWRCB staff to review the FPGP applications package.

## 1.2 FPGP Application Preparation

- V WSC will complete the application form and compile SSLOCSD's resolution authorizing the FPGP grant application.
- V WSC will prepare the Plan of Study consisting of the following components
- A description of the recycled water service area that will be studied
- 2 The potential sources of recycled water and a summary of the unit processes currently in use at existing treatment facilities.
- 'n A description of the current disposal/reuse of the wastewater that is proposed to be
- 4. A map of the study area showing the sources of recycled water and potential service
- 5 Identification of the water and wastewater agencies having jurisdictions over the sources of recycled water and/or the potential service area.
- 6. A general description of water recycling and potable water supply alternatives that will be evaluated
- 7. A description of the opportunities for stakeholder participation, for example, public other agencies that have a stake in the study. meeting with the local community members, potential recycled water users, and

- œ facilities planning study. A schedule with the start and completion dates of major tasks associated with the
- 9. description of the proposed actions to reduce the impact of these potential A list of potential problems that may cause delay in the progress of the study and
- 10. Identification of the entities that will be conducting the study and description of consultants or interagency agreements with other agencies, and any force account their roles. This may include a description of proposed subcontracts with
- Proposed budget for the study, including estimated costs of specific tasks, sources of financing, and sources of funds for cash flow until grant reimbursement
- V WSC will make necessary adjustments to the FPGP application package components after the SWRCB to issue a grant commitment. review meeting with the SWRCB to obtain approval of the Plan of Study, thus allowing the

# TASK 2.0 RECYCLED WATER FACILITIES PLANNING STUDY PREPARATION

#### 2.0 Investment Analysis

### 2.0.1 Conceptual Design Criteria

- of Arroyo Grande through review of SSLOCSD Hydraulic Model. Quantify the amount of water available for a SWRRF along the SSLOCSD trunklines from the City
- V the facility will include the following: Define conceptual design criteria for the facility. It is anticipated that the conceptual design for
- Capacity to treat current Average Dry Weather Flow (ADWF)
- Advanced level of treatment suitable for groundwater recharge
- Solids conveyed downstream with membrane concentrate
- V It is assumed that the SSLOCSD will provide information on potential locations and corresponding land acquisition costs for the treatment and recharge facilities

#### 2.0.2 Cost Estimates

- V collection system Develop planning level cost estimates for constructing and operating a SWRRF in the SSLOCSD
- V meet the redundancy requirements for comparison with the SWRRF. Utilize existing planning level cost estimates for alternative SSSLOCSD WWTP improvements to
- V Utilize planning level cost estimates for supplemental water supply alternatives. Cost estimates to be obtained from the Pismo Beach Recycled Water Facilities Planning Study

#### 2.0.3 Investment Analysis

- redundancy requirements and supplemental water supply alternatives. Compare planning level cost estimates for the SWRRF against cost estimates for SSLOCSD
- Evaluate and summarize key considerations and constraints for project implementation

### 2.0.4 Draft Investment Analysis TM

Prepared draft Investment Analysis TM documenting the results of the Investment Analysis

Deliverable: Draft Investment Analysis TM

## 2.0.5 Investment Analysis Review Meeting

Plan, schedule and lead a meeting with SSLOCSD staff (and key stakeholders as appropriate) to review the results of the Investment Analysis.

meeting will provide summary notes with action items within five (5) working days following the meeting. Deliverable: WSC will provide agenda and meeting materials at least three (3) working days prior to the

### 2.0.6 Final Investment Analysis TM

Prepared a final Investment Analysis TM that incorporates comments from SSLOCSD staff and other stakeholders

Deliverable: Final Investment Analysis TM

### 2.1 Project Management

### 2.1.1 Project Administration

#### 2.1.1.1 Project schedule

V Prepare project schedule and update as-required based upon actual progress and SSLOCSD direction. Submit revised schedules to the SSLOCSD as necessary.

#### 2.1.1.2 Progress reports

Prepare progress reports to be submitted with each monthly invoice. The reports will include: 1) coordination needs; and 3) schedule updates. summary of activities accomplished in the current month; 2) outstanding information and/or

project schedules as-needed throughout the project. WSC will provide monthly progress reports with project Deliverable: WSC will provide a preliminary project schedule at the Kickoff Meeting and will provide updated

#### 2.1.2 Kickoff Meeting

V WSC will plan, organize and facilitate a Kickoff Meeting with SSLOCSD staff

- V involvement during the project; (7) discuss and develop strategies for stakeholder involvement; set dates/times for the subsequent workshops; (6) confirm level and nature of SWRCB including the Study Parameters identified in the Plan of Study approval by the SWRCB; (2) methodologies; (3) identify data needs and sources; (4) define coordination requirements; (5) The purpose of the meeting will be to: (1) discuss the goals and objectives of the Planning Study items and required follow-up. (8) finalize the conceptual design criteria for the Investment Analysis; and (9) identify action review the scope and schedule of the project including assumptions and proposed
- V Budget is based on a 2-hour meeting attended by WSC's Principal, Associate Engineer I, and Assistant Engineer.

meeting. Deliverable: WSC will provide agenda and meeting materials at least three (3) working days prior to the meeting and will provide summary notes with action items within three (3) working days following the

#### 2.1.3 Workshops

## 2.1.3.1 Workshop #1: Conceptual Alternatives Development

- (1) Plan, schedule and lead a workshop with SSLOCSD staff (and key stakeholders as appropriate) to develop conceptual alternatives for the SWRRF, including customer/use type, treatment, storage, and distribution. The workshop is anticipated to include the following topics:
- (a) Review water supplies and characteristics (Task 2.3)
- (b) Review wastewater characteristics and facilities (Task 2.4)
- (c) Review treatment requirements (Task 2.5)
- (d) Review recycled water market/opportunities (Task 2.6)
- (e) Review legal, permitting and environmental criteria (Task 2.7)
- (f) Review planning and design assumptions (Task 2.8.1)
- (g) Develop up to three (3) conceptual treatment alternatives
- (h) Develop up to three (3) conceptual distribution alternatives
- (i) Develop up to three (3) conceptual storage alternatives
- (j) Develop non-recycled water alternative
- (2) Budget is based on a 3-hour workshop attended by WSC's Principal, Associate Engineer I, Assistant Engineer, and Staff Planner II.

## 2.1.3.2 Workshop #2: Alternatives Evaluation and Screening

- (1) Coordinate a workshop with SSLOCSD staff to evaluate and screen each of the alternative for treatment, storage and distribution. conceptual alternatives developed in Workshop #1, and to develop/select a preferred
- 2 Develop screening/evaluation criteria for the conceptual alternatives, including:
- (a) Cost (capital, O&M, NPV, EAC and \$/AF)
- (b) Water supply benefits
- (c) Water quality considerations
- (d) Flexibility, expandability
- (e) Sequencing/phasing/schedule considerations
- f) Consistency with project goals/objectives
- (3) Evaluate and compare the conceptual alternatives by applying the selected screening/evaluation criteria
- (4) Select the preferred project alternative, which may combine aspects/components of more than one conceptual alternative
- (5) Budget is based on a 3-hour workshop attended by WSC's Principal, Associate Engineer I, Assistant Engineer, and Staff Planner II.

workshop and will provide summary notes with action items within three (3) working days following the Deliverable: WSC will provide agenda and meeting materials at least three (3) working days prior to each meeting.

### 2.1.4 Deliverable Review Meetings

- 2.1.4.1 Deliverable Review Meeting #1: Druft Recycled Water Facilities Planning Study
- (1) Plan, schedule and lead a meeting to review the draft recycled water facilities planning
- (2) Budget is based on a 2-hour meeting attended by WSC's Principal, Associate Engineer I, and Assistant Engineer.
- 2.1.4.2 Deliverable Review Meeting #2: Final Draft Recycled Water Facilities Planning Study
- Plan, schedule and lead a meeting to review the final draft recycled water facilities planning study
- (2) Budget is based on a 2-hour meeting attended by WSC's Principal, Associate Engineer I, and Assistant Engineer.

Deliverable: WSC will provide agenda and meeting materials at least three (3) working days prior to the meeting and will provide notes with action items within three (3) working days following the meeting.

#### 2.2 Background

#### 2.2.1 Study Area

- Prepare a summary of the Study Area that includes:
- (1) Narrative description of the Study Area
- (2) Descriptive maps and diagrams showing vicinity, jurisdictional boundaries, proposed annexation areas, regional topography/geography, groundwater basin boundaries, hydrologic features, and current and projected land use.
- V The proposed Study Area shall include the current SSLOCSD service area, proposed scalping Northern Cities Management Area (NCMA). locations along the SSLOCSD trunk lines for the City of Arroyo Grande, and the remainder of the

#### 2.2.2 Goals and Objectives

Summarize goals and objectives defined during the Kickoff Meeting

## 2.3 Water Supplies and Characteristics

### 2.3.1 Water supply characteristics

- Summarize current and projected water supplies for the Member agencies based on 2010 Urban Water Management Plans (2010 UWMPs) and NCMA Technical Group (TG) Annual Reports.
- For each water supply source, summarize:
- (1) Source characteristics
- (2) Capacities of existing facilities
- (3) Wholesale agencies and delivery mechanisms
- (4) Fixed and variable costs
- (5) Management considerations including reliability
- (6) Water quality considerations

### 2.3.2 Water Demand Characteristics

Summarize current and projected water demand from 2010 UWMPs and NCMA TG Annual

#### 2.3.3 Water Pricing

V upcoming rate increases. Summarize the current water rate structures for the MEMBER Agencies and any planned or

## 2.4 Wastewater Characteristics and Facilities

#### 2.4.1 Existing Facilities

- V description of treatment processes and design criteria. It is assumed that this information will be readily available from previous documents. Describe existing wastewater treatment plant facilities including capacity, current flows,
- Summarize the SSLOCSD's existing waste discharge requirements
- V estimates will be available from previous studies. Characterize current and projected future influent flows. It is assumed that flow projection
- V Characterize current effluent water quality including any seasonal variation
- V and control measures Summarize source(s) of industrial or other problem constituents (including high-TDS infiltration)
- V (MM), maximum day (MD), peak hour wet weather flow (PHWWF) Summarize current wastewater flow variations including peaking factors for maximum month
- V (none expected) Describe existing recycling including users, quantities, and contractual and pricing arrangements
- Summarize existing rights to use of treated effluent after discharge (none expected)

#### 2.4.2 Future Facilities

- Outline expected future waste discharge requirements based on conversations with the SSLOCSD staff, review of the Basin Plan, and meetings with SSLOCSD staff and the Regional Water Quality Control Board
- V Describe plans for new wastewater treatment facilities to achieve regulatory compliance

### 2.5 Treatment Requirements

## 2.5.1 Recycled Water Quality Requirements

- Describe required water qualities and/or treatment requirements for each category of potential recycled water use
- V and groundwater recharge Describe regulatory requirements for recycled water including Title 22 unrestricted irrigation,
- Describe Basin Plan requirements for recycled water use
- V from problems resulting from recycled water Describe water quality related requirements of the RWQCB to protect surface or ground water
- V Describe operational and on-site requirements for recycled water (such as backflow prevention, buffer zones, etc.)

## 2.6 Recycled Water Market/Opportunities

### 2.6.1 Update Market Analysis

- identified in the Regional Recycled Water Strategic Plan Obtain and review recent customer consumption data for potential recycled water customers
- water and quality of use, quality and reliability needs and wastewater disposal methods. recycled water, date of possible initial use of recycled water, present and future source(s) of investment required (on-site conversion costs), needed water cost savings, desire to use potential user, summarize type of use, expected annual use, peak use, estimated internal capital Describe validation and market analysis methodology. For each identified user or category of

## 2.6.2 Preliminary Market Assurances

- identified customers within their service area. assumed that the member agencies will assist in contacting and obtaining assurances from the preliminary assurance in the form of a letter, email or other form of correspondence. It is potential customers (in terms of total projected recycled water use) and attempt to obtain a market assurances. It is anticipated that WSC would develop a plan to approach the top 20 Contact a representative sample of potential future recycled water users and obtain preliminary
- V Develop map of proposed service area based on results of market assessment

## 2.7 Legal, Permitting and Environmental Criteria

## 2.7.1 Tentative Water Recycled Requirements of RWQCB

Contact RWQCB to obtain preliminary requirements for development of a recycled water treatment and distribution system.

### 2.7.2 Permitting Requirements

- Identify and summarize the probable permitting requirements for implementing recycled water summary of probable permitting requirements. projects. Utilize previously completed recycled water studies as the basis for developing the
- V It is assumed that the SSLOCSD staff will take the lead in coordinating with the RWQCB and obtaining approval for utilizing a SWRRF to meet the WWTP's redundancy requirements.

### 2.7.3 Water Rights Considerations

have on the NCMA Agencies' water rights Summarize potential water rights impacts the development of the recycled water program could

## 2.7.4 Environmental Documentation Requirements (CEQA)

Research and summarize the necessary environmental documentation requirements to implement a recycled water program

### 2.8 Project Alternatives Analysis

## 2.8.1 Planning and Design Assumptions

- evaluating project alternatives. These assumptions should include: Develop relevant planning and design assumptions and criteria that will be used when
- (1) Delivery and system pressure criteria
- (2) Peak delivery criteria
- (3) Storage criteria
- **(**4) Cost basis: key assumptions; cost index; cost escalation and contingency factors; discount rate; evaluation term for present worth analysis; etc.
- (5) Planning period
- (6) Conceptual infrastructure design criteria

## 2.8.2 Alternatives Development - Treatment

- Develop up to two (2) conceptual facility alternatives for each of the following levels of
- (1) Title 22 unrestricted irrigation
- (2) Partial Reverse Osmosis
- (3) Groundwater recharge (Advanced Treatment)
- > Each conceptual treatment alternative will include:
- (1) Narrative description including summary of required unit processes and summary of pros, cons and/or key considerations
- (2) Simplified process flow diagram
- (3) Conceptual location and layout
- Preliminary estimates of capital and O&M cost, net present value, equivalent annual cost, and cost per acre-foot of supply

## 2.8.3 Alternatives Development - Distribution systems

- V Develop up to two (2) conceptual distribution system alternatives for each of the following levels of treatment:
- (1) Title 22 unrestricted irrigation
- (2) Groundwater recharge (Advanced Treatment)
- Analysis of groundwater recharge distribution alternatives will be based upon findings from the Pismo Beach Recycled Water Facilities Planning Study.
- V improvements, and will include: Each conceptual distribution system alternative will describe pumping and piping

- 1 Narrative description including summary of required infrastructure and summary of pros, cons and/or key considerations
- (2) Conceptual location and layout
- Preliminary estimates of capital and O&M cost, net present value, equivalent annual cost, and cost per acre-foot of supply

## 2.8.4 Alternatives Development – Recycled Water Storage

- Develop up to two (2) conceptual alternatives for recycled water system storage. conceptual alternative will include:
- (1) Narrative description including summary of required infrastructure and summary of pros, cons and/or key considerations
- (2) Conceptual location and layout
- (3) Preliminary estimates of capital and O&M cost, net present value, equivalent annual cost, and cost per acre-foot of supply

## 2.8.5 Non-recycled Water Alternative

- supply alternative: Review the following previously completed studies to identify a preferred non-recycled water
- (1) 2010 Urban Water Management Plan (WSC, 2011)
- (2) Lopez Lake Spillway Raise Project (Stetson 2012)
- (3) Desalination Water Supply Study (Wallace 2006)
- (4)SSLOCSD of Arroyo Grande Water Supply Alternative Study (Wallace 2004)
- (5)South San Luis Obispo County Desalination Funding Study (Wallace 2008)
- (6) Coastal Branch Capacity Assessment (WSC 2011)
- (7) Other relevant water supply studies
- V Summarize existing estimates of capital and O&M cost, net present value, equivalent annual cost, and cost per acre-foot of the non-recycled water supply based on previously completed

## 2.8.6 Water Conservation/Reduction Analysis

- V Summarize the MEMBER agencies' current and future plans for water conservation. WSC will conservation summary. utilize 2010 UWMPs, NCMA TG reports, and other available resources as the basis for a water
- 2.8.7 No Project Alternative
- Evaluate the no project alternative and include in alternatives analysis

## 2.8.8 Conceptual Alternatives Analysis

Summarize the outcome from Workshop #2 including

- (1) Screening/evaluation criteria
- (2) Results from the screening/evaluation
- Preferred conceptual alternatives for treatment, distribution and storage

## 2.9 Recommended Facilities Project Plan

#### 2.9.1 Preferred Alternative

- Develop preliminary design criteria and refined pipeline routes for the preferred alternative
- V treatment, distribution and storage alternatives Prepare updated maps, figures, process flow diagram(s), and layouts to reflect the preferred
- V Update cost estimates based on final configuration and considering expected time of
- V Prepare list of all potential users, quantity of recycled water use, peak demand and commitments obtained to-date
- V Compare reliability of the recycled water facilities to the user requirements
- Summarize on-site improvements required including cost
- V infrastructure. Provide phasing considerations/recommendations in the preferred project plan. and construction of the treatment plant upgrades and construction of the distribution system Prepare a schedule for the implementation of the recycled water project that includes design

### 2.10 Stakeholder Involvement

### 2.10.1 Stakeholder Outreach

- Conduct stakeholder meetings to coordinate project objectives, elements, etc. Document stakeholder outreach efforts.
- Budget based on three (3) 1-hr meetings attended by WSC's Principal and Associate Engineer I.

#### 2.10.2 Public Outreach

- of an explanatory presentation and/or graphics presenting the analysis and/or conclusions Provide project updates at public meetings as requested by the SSLOCSD, including preparation contained within the Recycled Water Facilities Planning Study
- Document public outreach efforts.
- V Budget based on two (2) 1-hr meetings attended by WSC's Principal and Associate Engineer I.

### 2.11 Implementation Plan

### 2.11.1 Coordination and Governance

Determine needed agreements and ordinances for implementing a preferred alternative recycled water system.

- V course of action. Evaluate recycled water mandatory use ordinances and provide SSLOCSD with recommended
- Prepare a draft user contract for connecting customers

## 2.11.2 Construction Financing Plan and Revenue Program

- Prepare funding plan that outlines sources and timing of funds for design and construction.
- Summarize pricing policy recommendations for recycled water
- Evaluate costs that can be allocated to water pollution control and/or water supply reliability
- Develop criteria and annual projections for:
- (1) Water prices for each user or category of users
- (2) Recycled water used by each user
- (3) Annual costs (required revenue) of recycling project
- (4) Allocation of costs to users
- (5) Unit costs to serve each user or category of users
- (6) Sensitivity analysis assuming portion of potential users fail to use recycled water

#### 2.11.3 Detailed Schedule

customer improvements. design and construction, critical milestones from the financing and revenue program and on-site Develop a detailed schedule for the implementation of the recycled water project that includes

# 2.12 Prepare Recycled Water Facilities Planning Study

## 2.12.1 Prepare Draft Recycled Water Facilities Planning Study

Prepare draft Executive Summary and compile draft report including title page(s), and appendices. acknowledgements, table of contents, list of figures, list of tables, draft chapters, reference list

Deliverable: Draft Recycled Water Facilities Planning Study

## 2.12.2 Final Draft Recycled Water Facilities Planning Study

Prepare Final Draft Recycled Water Facilities Planning Study based on comments received from the SSLOCSD and any identified stakeholders on the draft Recycled Water Facilities Planning

Deliverable: Final Draft Recycled Water Facilities Planning Study

## 2.12.3 Final Recycled Water Facilities Planning Study

SSLOCSD on the Final Draft Recycled Water Facilities Planning Study. Prepare Final Recycled Water Facilities Planning Study based on comments received from the

Deliverable: Final Recycled Water Facilities Planning Study

#### Deliverable Summary


2.12.3	2.12.2	2.12.1	2.1.4	2.1.3	2.1.2	2.1.1	2.0.6	2.0.5	2.0.4	1.2	Task
Final Recycled Water Facilities Planning Study	Final Draft Recycled Water Facilities Planning Study	Draft Recycled Water Facilities Planning Study	Deliverable Review Meetings #1 and #2 Agenda and Minutes	Workshops #1 and #2 Agenda and Minutes	Kickoff Meeting Agenda and Minutes	Project Schedule	Final Investment Analysis TM	Investment Analysis TM Review Meeting Agenda and Minutes	Draft Investment Analysis TM	FPGP Application	Deliverable Description
Emailed PDF and four (4) hardcopies	Emailed PDF and four (4) hardcopies	Emailed PDF and four (4) hardcopies	Emailed PDF	Emailed PDF	Emailed PDF	Emailed PDF and 11x17 hardcopies for all meeting attendees	Emailed PDF	Emailed PDF	Emailed PDF	Emailed PDF	Format/Copies
See project schedule	See project schedule	See project schedule	See project schedule	See project schedule	See project schedule	At Kickoff Meeting and revised as-needed	See project schedule	See project schedule	See project schedule	See project schedule	Due Date

**Exhibit B: Fee Estimate** 

1.1       FPGP Application Management and Support       4       6       4       2       16       \$ 2, 2         1.2       FPGP Application Preparation       2       2       8       12       24       \$ 3, 3         2.0       Investment Analysis       -       10       8       24       50       0       0       92       \$ 13, 2         2.0.1       Conceptual Design Criteria       2       2       4       8       \$ 1, 2         2.0.2       Cost Estimates       2       6       8       20       36       \$ 5, 5         2.0.3       Investment Analysis       2       4       6       \$ 5         2.0.4       Draft Investment Analysis TM       2       2       4       12       20       \$ 2, 2         2.0.5       Investment Analysis Review Meeting       2       4       4       10       \$ 1, 2 </th <th>5,606 2,752 3,854 3,670 2,292 3,306 736 2,910 3,608 3,818 3,784 3,472</th> <th>\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$</th> <th>200 100 100 400 - 200 - 100 - 100 600</th> <th>\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$</th> <th>6,806 2,852 3,954 14,070 1,292 5,506 736 3,010 1,608</th>	5,606 2,752 3,854 3,670 2,292 3,306 736 2,910 3,608 3,818 3,784 3,472	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	200 100 100 400 - 200 - 100 - 100 600	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	6,806 2,852 3,954 14,070 1,292 5,506 736 3,010 1,608
Principal   Sr.Engineer   III   Associate Engineer   Engineer   Engineer   Assistant Engineer   E	5,606 2,752 3,854 3,670 2,292 3,306 736 2,910 3,608 3,818 3,784 3,472	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	200 100 100 400 - 200 - 100	\$ \$ \$ \$ \$ \$ \$	6,806 2,852 3,954 14,070 1,292 5,506 736 3,010
1.1       FPGP Application Management and Support       4       6       4       2       16       \$ 2, 2         1.2       FPGP Application Preparation       2       2       2       8       12       24       \$ 3, 3         2.0       Investment Analysis       -       10       8       24       50       0       0       92       \$ 13, 3         2.0.1       Conceptual Design Criteria       2       2       4       8       \$ 1, 3         2.0.2       Cost Estimates       2       6       8       20       36       \$ 5, 5         2.0.3       Investment Analysis       2       4       6       \$ 5         2.0.4       Draft Investment Analysis TM       2       2       4       12       20       \$ 2, 2         2.0.5       Investment Analysis Review Meeting       2       4       4       10       \$ 1, 2	2,752 3,854 3,670 2,292 3,306 736 3,910 3,608 3,818 3,784	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	100 100 400 - 200 - 100	\$ \$ \$ \$ \$ \$	2,852 3,954 14,070 1,292 5,506 736 3,010
1.2         FPGP Application Preparation         2         2         8         12         24         \$ 3,           2.0         Investment Analysis         -         10         8         24         50         0         0         92         \$ 13,           2.0.1         Conceptual Design Criteria         2         2         4         8         \$ 1,           2.0.2         Cost Estimates         2         6         8         20         36         \$ 5,           2.0.3         Investment Analysis         2         4         6         \$           2.0.4         Draft Investment Analysis TM         2         2         4         12         20         \$ 2,           2.0.5         Investment Analysis Review Meeting         2         4         4         10         \$ 1,           2.0.6         Final Investment Analysis TM         2         4         6         12         \$ 1,           2.1.1         Project Management         -         20         0         60         24         8         14         126         \$ 19,           2.1.1         Project Administration         2         30         14         46         \$ 6,           2	3,854 3,670 2,292 3,306 736 3,910 3,608 3,818 3,784 4,472	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	100 400 - 200 - 100 - 100	\$ \$ \$ \$ \$	3,954 14,070 1,292 5,506 736 3,010
2.0         Investment Analysis         -         10         8         24         50         0         0         92         \$ 13,           2.0.1         Conceptual Design Criteria         2         2         4         8         \$ 1,           2.0.2         Cost Estimates         2         6         8         20         36         \$ 5,           2.0.3         Investment Analysis         2         4         6         \$           2.0.4         Draft Investment Analysis TM         2         2         4         12         20         \$ 2,           2.0.5         Investment Analysis Review Meeting         2         4         4         10         \$ 1,           2.0.6         Final Investment Analysis TM         2         4         6         12         \$ 1,           2.1         Project Management         -         20         0         60         24         8         14         126         \$ 19,           2.1.1         Project Administration         2         30         14         46         \$ 6,           2.1.2         Kickoff Meeting         4         8         8         20         \$ 3,	,,670 ,,292 ,,306 ,736 ,,910 ,,608 ,,818 ,,784 ,,472	\$ \$ \$ \$ \$ \$ \$ \$ \$ \$ \$	400 - 200 - 100 - 100	\$ \$ \$ \$ \$	14,070 1,292 5,506 736 3,010
2.0.1       Conceptual Design Criteria       2       2       4       8       \$ 1,         2.0.2       Cost Estimates       2       6       8       20       36       \$ 5,         2.0.3       Investment Analysis       2       4       6       \$         2.0.4       Draft Investment Analysis TM       2       2       4       12       20       \$ 2,         2.0.5       Investment Analysis Review Meeting       2       4       4       10       \$ 1,         2.0.6       Final Investment Analysis TM       2       4       6       12       \$ 1,         2.1       Project Management       -       20       0       60       24       8       14       126       \$ 19,         2.1.1       Project Administration       2       30       14       46       \$ 6,         2.1.2       Kickoff Meeting       4       8       8       20       \$ 3,	,292 ,306 ,736 ,910 ,608 ,818 ,784 ,472	\$ \$ \$ \$ \$ \$ \$ \$	- 200 - 100 - 100	\$ \$ \$ \$	1,292 5,506 736 3,010
2.0.2       Cost Estimates       2       6       8       20       36       \$ 5, 5,         2.0.3       Investment Analysis       2       4       6       \$         2.0.4       Draft Investment Analysis TM       2       2       4       12       20       \$ 2,         2.0.5       Investment Analysis Review Meeting       2       4       4       10       \$ 1,         2.0.6       Final Investment Analysis TM       2       4       6       12       \$ 1,         2.1       Project Management       -       20       0       60       24       8       14       126       \$ 19,         2.1.1       Project Administration       2       30       14       46       \$ 6,         2.1.2       Kickoff Meeting       4       8       8       20       \$ 3,	736 736 7,910 7,608 7,818 7,784 7,784	\$ \$ \$ \$ \$	200 - 100 - 100	\$ \$ \$	5,506 736 3,010
2.0.3       Investment Analysis       2       4       6       \$         2.0.4       Draft Investment Analysis TM       2       2       4       12       20       \$       2         2.0.5       Investment Analysis Review Meeting       2       4       4       10       \$       1,         2.0.6       Final Investment Analysis TM       2       4       6       12       \$       1,         2.1       Project Management       -       20       0       60       24       8       14       126       \$       19,         2.1.1       Project Administration       2       30       14       46       \$       6,         2.1.2       Kickoff Meeting       4       8       8       20       \$       3,	736 ,910 ,608 ,818 ,784 ,472	\$ \$ \$ \$	- 100 - 100	\$ \$ \$	736 3,010
2.0.4     Draft Investment Analysis TM     2     2     4     12     20     \$ 2, 2       2.0.5     Investment Analysis Review Meeting     2     4     4     10     \$ 1, 10     \$ 1, 10       2.0.6     Final Investment Analysis TM     2     4     6     12     \$ 1, 10       2.1     Project Management     -     20     0     60     24     8     14     126     \$ 19, 14       2.1.1     Project Administration     2     30     14     46     \$ 6, 20       2.1.2     Kickoff Meeting     4     8     8     20     \$ 3, 30	,910 ,608 ,818 ,784 ,472	\$ \$ \$ \$	100 - 100	\$	3,010
2.0.5     Investment Analysis Review Meeting     2     4     4     10     \$ 1,       2.0.6     Final Investment Analysis TM     2     4     6     12     \$ 1,       2.1     Project Management     -     20     0     60     24     8     14     126     \$ 19,       2.1.1     Project Administration     2     30     14     46     \$ 6,       2.1.2     Kickoff Meeting     4     8     8     20     \$ 3,	,608 ,818 ,784 ,472	\$ \$ \$	100	\$	
2.0.6 Final Investment Analysis TM     2     4     6     12     \$ 1.       2.1 Project Management     - 20     0     60     24     8     14     126     \$ 19,       2.1.1 Project Administration     2     30     14     46     \$ 6,       2.1.2 Kickoff Meeting     4     8     8     20     \$ 3,	,818 ,784 ,472	\$	100		1,608
2.0.6     Final Investment Analysis TM     2     4     6     12     \$ 1,       2.1     Project Management     -     20     0     50     24     8     14     126     \$ 19,       2.1.1     Project Administration     2     30     14     46     \$ 6,       2.1.2     Kickoff Meeting     4     8     8     20     \$ 3,	,818 ,784 ,472	\$			
2.1         Project Management         -         20         0         60         24         8         14         126         \$ 19,           2.1.1         Project Administration         2         30         14         46         \$ 6,           2.1.2         Kickoff Meeting         4         8         8         20         \$ 3,	,784	\$			1,918
2.1.2 Kickoff Meeting 4 8 8 20 \$ 3,		c	טטט	\$	20,384
2.1.2         Kickoff Meeting         4         8         8         20         \$ 3,		1 >	200	\$	6,672
	,216	_	100		3,316
2.1.3 Workshops 8 14 10 8 40 \$ 6,			200		6,734
		\$	100	\$	3,662
2.2 Background - 0 2 5 0 12 0 19 \$ 2,	,824	\$	100	\$	2,924
2.2.1 Study Area 1 4 10 15 \$ 2,	,173	\$	100	\$	2,273
		\$	-	ŝ	651
		_	200	\$	4,338
			100	\$	2,011
		\$	100	Ś	2,327
		\$	200	\$	7,535
			100	\$	2,485
		\$	100	\$	5,050
			100	\$	1,926
		\$	100	\$	1,926
		\$	300	\$	9,944
		\$	200	\$	7,409
		\$	100	\$	2,535
			100	\$	6,896
		\$		\$	1,071
		\$	100	\$	3,082
		\$	-	\$	1,441
		\$	-	\$	1,302
		\$	700	\$	23,291
		\$		\$	1,071
		\$	300	\$	8,762
			200	\$	6,419

					F	ee Assessm	ent				
Task Description		Principal	Sr.Engineer III	Associate Engineer I	Assistant Engineer	Staff Planner II	Clerical/ Admin	Total Labor Hours	Total Labor Cost	Total Expenses	Total Fee
lternatives Development - Storage			1	4	10	2		17	\$ 2,175	\$ 100	\$ 2,275
on-recycled Water Alternative			1	2	4	2		9	\$ 1,229	\$ -	\$ 1,229
/ater conservation/reduction analysis						4		4	\$ 524	\$ -	\$ 524
o project alternative				2	4			6	\$ 736	\$ -	\$ 736
onceptual alternatives analysis			1	4	10	2		17	\$ 2,175	\$ 100	\$ 2,275
ecommended Facilities Project Plan		4	4	24	20	8	0	60	\$ 8,976	\$ 300	\$ 9,276
referred alternative		4	4	24	20	8		60	\$ 8,976	\$ 300	\$ 9,276
takeholder Involvement	DHI-E	5	0	12	8	28	0	53	\$ 7,794	\$ 200	\$ 7,994
takeholder outreach		3		6	4	14		27	\$ 4,036	\$ 100	\$ 4,136
ublic outreach		2		6	4	14		26	\$ 3,758	\$ 100	\$ 3,858
nplementation Plan		6	10	18	26	16	0	76	\$ 11,648	\$ 400	\$ 12,048
oordination and governance		2	4	2	4	8		20	\$ 3,264	\$ 100	\$ 3,364
onstruction financing plan and revenue program		2	4	12	16	8		42	\$ 6,104	\$ 200	\$ 6,304
etailed schedule		2	2	4	6			14	\$ 2,280	\$ 100	\$ 2,380
repare Recycled Water Facilities Planning Study		16	16	48	68	42	0	190	\$ 28,370	\$ 900	\$ 29,270
raft Recycled Water Facilities Planning Study		6	6	24	28	18		82	\$ 12,144	\$ 400	\$ 12,544
nal Draft Recycled Water Facilities Planning Study		6	6	16	24	12		64	\$ 9,674	\$ 300	\$ 9,974
nal Recycled Water Facilities Planning Study		4	4	8	16	12		44	\$ 6,552	\$ 200	\$ 6,752
		-	-	200	240	252	9.5		450.000		\$ 156,702
nal Recycled Wate	er Facilities Planning Study  Column Totals										

ID	Task Name		n	uration	Start	Finish	Otr	1 2014	04-3 3011	04.3	2014	0	2044	10.		1					
טו	I GON INGILIE		L	uration	oldit	FII11511	Jan	1, 2014 Feb Mar	Qtr 2, 2014 Apr May	lun lul	, 2014 Aug	Qtr 4,	Nov D	Qtr :	L, 2015	Qtr 2, 201	5 Qt	r 3, 2015	Qtr 4	4, 2015	Qtr
1	Notice to proceed		0	days	Wed 12/17/2	14Wed 12/17/14	4	100 1 11101	, ipi   iiicy	3411   341	Trub I	JCP   OCT	NOV D	♦ 12/17	T ED   IVIA	Api   Ivid	/   Juli   Ju	ui   Aug	sep   Oct	NOVIL	Jec   Jar
2	1.0 FPGP Application Ass	istance	7	7 days	Wed 12/17/	14Thu 4/2/15								*		-					
3	1.1 FPGP Application M	lanagement and Support	4	0 days	Wed 12/17/2	14Tue 2/10/15								_		•					
4	1.2 FPGP Application Pr	eparation	4	wks	Fri 12/19/14	Thu 1/15/15								-							
5	SWRCB Review of FPGF	Application	8	wks	Fri 2/6/15	Thu 4/2/15									MANUFACTURE AND ADDRESS OF THE PARTY OF THE	-					
6	Notification of FPGP Ap	plication Approval	0	days	Thu 4/2/15	Thu 4/2/15															
7	2.0.1 Investment Analysis	5	4	5 days	Fri 2/6/15	Thu 4/9/15									<b>C</b>	==0.					
8	2.0.1 Conceptual Design	n Criteria	1	. wk	Fri 2/6/15	Thu 2/12/15									10-						
9	2.0.2 Cost Estimates		2	wks	Fri 2/13/15	Thu 2/26/15															
10	2.0.3 Investment Analy	sis	1	wk	Fri 2/27/15	Thu 3/5/15									*						Automorphic Co.
11	2.0.4 Draft Investment	Analysis TM	2	wks	Fri 3/6/15	Thu 3/19/15									1						
12	SSLOCSD Review of Dra	ft Investment Analysis TM	2	wks	Fri 3/20/15	Thu 4/2/15									1						
13	2.0.5 Investment Analy	sis Review Meeting	0	days	Thu 4/2/15	Thu 4/2/15			(A)	1						4/2					
14	2.0.6 Final Investment	Analysis TM	2	wks	Fri 4/3/15	Thu 4/16/15															
15	Task 2.1 Project Manager	nent	1	60 days	Fri 4/17/15	Thu 11/26/15			-	),						<b>V</b>					
16	2.1.1 Project Administr	ation	1	.60 days	Fri 4/17/15	Thu 11/26/15			200		(A)					Name and					
17	2.1.2 Kickoff Meeting		5	days	Fri 4/17/15	Thu 4/23/15					1					*					
18	2.1.3 Workshops		2	5 days	Thu 5/28/15	Thu 7/2/15															
19	Workshop #1 - Conce	eptual Alternatives Development	0	days	the state of the s	Thu 5/28/15		1	- TA								5/28				
20	Workshop #2 - Alterr	natives Screening		days		Thu 7/2/15			100	_ W							<b>∲</b> 27	1/2			
21	2.1.4 Deliverable Revie	w Meetings	4	0 days	Thu 9/24/15	Thu 11/19/15		- 6									11		Ç-		
22	Deliverable Review N	Neeting #1 - Draft RWFPS	0	days	Thu 9/24/15	Thu 9/24/15	1	P 1											9/24		
23	Deliverable Review N	Meeting #2 - Final Draft RWFPS	0	days	Thu 11/19/1	5 Thu 11/19/15														<b>♦ 11</b>	1/19
24	Task 2.2 Background		1	0 days	Fri 4/24/15	Thu 5/7/15										-				1	
25	2.2.1 Study Area		1	0 days	Fri 4/24/15	ACCOUNT OF THE PARTY OF THE PAR															
26	2.2.2 Goals and Objecti	ves		0 days	the second second second second second	Thu 5/7/15										T			į.		
27	Task 2.3 Water Supplies a	and Characteristics	1	0 days	Fri 4/24/15	Thu 5/7/15	M									-					
28	2.3.1 Water Supply Cha	racteristics	1	0 days	Fri 4/24/15	Thu 5/7/15	1												-		
29	2.3.2 Water Demand Ch	naracteristics	1	0 days	Fri 4/24/15	Thu 5/7/15															
30	2.3.3 Water Pricing		1	0 days	Fri 4/24/15	Thu 5/7/15	1														
31	Task 2.4 Wastewater Cha	racteristics and Facilities	3	5 days	Fri 4/24/15	Thu 6/11/15	1										#				
32	2.4.1 Existing Facilities			5 days	Fri 4/24/15	Thu 5/28/15													i		
33	2.4.2 Future Facilities		1	0 days	Fri 5/29/15	Thu 6/11/15															
34	Task 2.5 Treatment Requi	rements		0 days	Fri 4/24/15	Thu 5/7/15											$T \perp \downarrow \downarrow$				
35	2.5.1 Recycled Water Q			0 days	Fri 4/24/15	Thu 5/7/15															
36	Task 2.6 Recycled Water I			5 days	Fri 4/24/15	Thu 5/28/15															
37	2.6.1 Update Market Ar			0 days	Fri 4/24/15	Thu 5/21/15										The same of			1		
38	2.6.2 Preliminary Marke			5 days	Fri 4/24/15	Thu 5/28/15										+					
39	The state of the s	and Environmental Criteria		0 days	Fri 4/24/15												<del> </del>   -			-	
		Task		DI C			,										-11-				
				Project Su	**************************************			ctive Milestor				lanual Summ		up		Deadline		*			
	t: Schedule_SWRRF RWFPS	Split	CELEBRATE.	External T				ctive Summar	у		-♥ M	lanual Summ	nary	<u></u>		Progress		CALLERY			
Date:	Thu 1/29/15	Milestone •		External N	lilestone	Φ.	Ma	nual Task			St St	tart-only		Е							
		Summary		Inactive Ta	ask (		Du	ration-only	- 000		Fi.	inish-only		3							



	Task		Project Summary	Ç	Inactive Milestone	0	Manual Summary Rollup		Deadline	<b>.</b>
Project: Schedule_SWRRF RWFPS	Split	111111111111111111111111111111111111111	External Tasks		Inactive Summary		Manual Summary		Progress	
Date: Thu 1/29/15	Milestone	•	External Milestone	•	Manual Task		Start-only	С		
	Summary	<u> </u>	Inactive Task		Duration-only		Finish-only	3		
hu 1/29/15	3.00				Page 2 of 2					

#### **RESOLUTION NO. 2015-324**

# A RESOLUTION OF THE SOUTH SAN LUIS OBISPO COUNTY SANTITATION DISTRICT BOARD OF DIRECTORS APPROVING THE ADOPTION FOR A SUBMITTAL OF A GRANT APPLICATION FOR PREPARATION OF PLANNING STUDY FOR A RECYCLED WATER PROJECT

planning study of a Recycled Water Project, and from the State Water Resources Control Board in the amount not to exceed \$75,000 for a facilities Obispo County Sanitation District, a Water Recycling Facilities Planning Grant Application for a grant designee is hereby authorized and directed to sign and file, for and on behalf of the South San Luis BE IT RESOLVED by the South San Luis Obispo County Sanitation District that the District Manager or his

will comply with all applicable state statutory and regulatory requirements related to any state grant BE IT RESOLVED that the South San Luis Obispo County Sanitation District hereby agrees and further funds received, and does authorize the aforementioned representative or his designee to certify that the Agency has and

or change orders thereto on behalf of the South San Luis Obispo County Sanitation District. Sanitation District is hereby authorized to negotiate and execute a grant contract and any amendments BE IT FURTHER RESOLVED that the District Manager or his designee of the South San Luis Obispo County

#### CERTIFICATION

I do hereby certify that the foregoing is a full, true, and correct copy of a resolution duly and regularly adopted at a meeting of the South San Luis Obispo County Sanitation District held on February 4, 2015.

**Richard Sweet** 

Michael W. Seitz District Legal Counsel